

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

NOTE
WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

1. COUNTY Manitowish CHECK ONE Town Village City NAME Prairie du Chien

2. LOCATION - 1/4 Section NW 1/4 Section 12 Township T7N Range R6W 3. OWNER AT TIME OF DRILLING Marnen Morand
OR - Grid or street no. Street name ADDRESS

AND - If available subdivision name, lot & block no. POST OFFICE Prairie du Chien

4. Distance in feet from well to nearest: (Record answer in appropriate block)
BUILDING C.I. 30 SANITARY SEWER TILE FLOOR DRAIN C.I. FOUNDATION DRAIN SEWER CONNECTED INDEPENDENT WASTE WATER DRAIN C.I. TILE

CLEAR WATER DRAIN C.I. TILE SEPTIC TANK PRIVY SEEPAGE PIT ABSORPTION FIELD BARN SILO ABANDONED WELL SINK HOLE
70

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: house

6. DRILLHOLE						9. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
10	Surface	302				Trenton Lime	Surface	40	
6	302	363				St Peter	40	153	
						Mag Lime	153	363	

7. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	New Steel T+C 19.18	Surface	302

8. GROUT OR OTHER SEALING MATERIAL Kind Cement From (ft.) Surface To (ft.) 302
10. TYPE OF DRILLING MACHINE USED Cable Tool Direct Rotary Reverse Rotary Rotary - air w/drilling mud Rotary - hammer with drilling mud & air Jetting with Air Water
Well construction completed on 11-20 19 72

11. MISCELLANEOUS DATA Yield test: 2 Hrs. at 20 GPM Well is terminated 8 inches above below final grade
Depth from surface to normal water level 250 ft. Well disinfected upon completion Yes No
Depth to water level when pumping 290 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: Sept 11 19 73

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Ralph Faherty Registered Well Driller COMPLETE MAIL ADDRESS FAHERTY DRILLING CO., INC.
1120 Broadway
PLATTEVILLE, WISCONSIN 53818

COLIFORM TEST RESULT 436 GAS - 24 HRS. GAS - 48 HRS. CONFIRMED REMARKS
REV. 3-71