

APR 27 1976

NOTE

WHITE COPY - DIVISION'S COPY  
GREEN COPY - DRILLER'S COPY  
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE  Town  Village  City Prairie du Chien NAME

2. LOCATION - 1/4 Section SW Section 14 Township 7N Range 6W 3. OWNER AT TIME OF DRILLING Ed Goree

OR - Grid or street no. Street name ADDRESS R1

AND - If available subdivision name, lot & block no. POST OFFICE Prairie du Chien, Wis. 53821

4. Distance in feet from well to nearest: (Record answer in appropriate block)

BUILDING	SANITARY SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE WATER DRAIN
C. I.	C. I.	C. I.	SEWER CONNECTED	INDEPENDENT
TILE	TILE	TILE		
<u>12'</u>	<u>20'</u>	<u>20'</u>		

CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILLO	ABANDONED WELL	SINK-HOLE
C. I.	TILE							
	<u>60'</u>			<u>75'</u>	<u>90'</u>		<u>30'</u>	

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Country Home

6. DRILLHOLE						9. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
<u>10</u>	<u>Surface</u>	<u>42</u>	<u>6</u>	<u>42</u>	<u>120</u>	<u>Clay &amp; loose stone</u>	<u>Surface</u>	<u>25</u>	
						<u>hard limestone</u>	<u>25</u>	<u>120</u>	

7. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel plain end 18.97 A-53</u>	<u>Surface</u>	<u>42</u>
	<u>Valley steel</u>		
	<u>Pitless adaptor</u>		

8. GROUT OR OTHER SEALING MATERIAL			10. TYPE OF DRILLING MACHINE USED		
Kind	From (ft.)	To (ft.)	<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Direct Rotary	<input type="checkbox"/> Reverse Rotary
<u>Clay</u>	<u>Surface</u>	<u>8</u>	<input type="checkbox"/> Rotary - air w/drilling mud	<input checked="" type="checkbox"/> Rotary - hammer <u>w/air</u>	<input type="checkbox"/> Jetting with <input type="checkbox"/> Air <input type="checkbox"/> Water
<u>Cement</u>	<u>8</u>	<u>42</u>	Well construction completed on <u>4-19-1976</u>		

11. MISCELLANEOUS DATA		
Yield test:	<u>3</u> Hrs. at	<u>5</u> GPM
Depth from surface to normal water level	<u>60</u> ft.	Well is terminated <u>10</u> inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade
Depth to water level when pumping	<u>68</u> ft.	Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Water sample sent to <u>Madison</u>		Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
		laboratory on: <u>4-21-1976</u>

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coplan Registered Well Driller COMPLETE MAIL ADDRESS Boscobel R3 Box 84 Wis. 53805

Please do not write in space below

COLIFORM TEST RESULT <u>438</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
------------------------------------	---------------	---------------	-----------	---------