

WELL CONSTRUCTOR'S REPORT  
FORM 3300-15

NOTE **OCT 13 1975**

WHITE COPY - DIVISION'S COPY  
GREEN COPY - DRILLER'S COPY  
YELLOW COPY - OWNER'S COPY

STATE OF WISCONSIN  
DEPARTMENT OF NATURAL RESOURCES  
Box 450  
Madison, Wisconsin 53701

1. COUNTY Crawford CHECK ONE  Town  Village  City NAME Prairie du Chien

2. LOCATION - 1/4 Section SW Section 16 Township 7N Range 6W

OR - Grid or street no. Street name ADDRESS R7D

AND - If available subdivision name, lot & block no. POST OFFICE Prairie du Chien, Wis. 53821

3. OWNER AT TIME OF DRILLING Arthur Moan

4. Distance in feet from well to nearest:

BUILDING	SANITARY SEWER C. I.	FLOOR DRAIN C. I.	FOUNDATION DRAIN SEWER CONNECTED	WASTE WATER DRAIN C. I.
<u>15'</u>	<u>25'</u>	<u>25'</u>	<input type="checkbox"/>	<input type="checkbox"/>

CLEAR WATER DRAIN C. I.	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
	<u>65'</u>			<u>90'</u>				

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Country home

6. DRILLHOLE						9. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>25</u>	<u>6</u>	<u>25</u>	<u>140</u>	<u>Clay</u>	<u>Surface</u>	<u>25</u>
						<u>loose sand</u>	<u>25</u>	<u>100</u>
						<u>Sandstone</u>	<u>100</u>	<u>140</u>

7. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel plain end 18.97</u>	<u>Surface</u>	<u>113</u>

8. GROUT OR OTHER SEALING MATERIAL			10. TYPE OF DRILLING MACHINE USED		
Kind	From (ft.)	To (ft.)	<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Direct Rotary	<input type="checkbox"/> Reverse Rotary
<u>puddled clay</u>	<u>Surface</u>	<u>25</u>	<input type="checkbox"/> Rotary - air w/drilling mud	<input checked="" type="checkbox"/> Rotary - hammer with drilling mud & air	<input type="checkbox"/> Jetting with <input type="checkbox"/> Air <input type="checkbox"/> Water
<u>loose sand</u>	<u>25</u>	<u>100</u>	Well construction completed on <u>9-20-1975</u>		

11. MISCELLANEOUS DATA		Well is terminated <u>8</u> inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade	
Yield test: <u>3 Hrs. at</u>	<u>8</u> GPM	Well disinfected upon completion	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Depth from surface to normal water level	<u>60</u> ft.	Well sealed watertight upon completion	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Depth to water level when pumping	<u>80</u> ft.	Water sample sent to <u>Madison</u> laboratory on: <u>10-8-1975</u>	

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coplan Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 84 Boscobel Wis., 53805

Please do not write in space below

COLIFORM TEST RESULT <u>442</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
---------------------------------	---------------	---------------	-----------	---------