

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

APR 5 1973

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

NOTE

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE Town Village City NAME Prairie du Chien

2. LOCATION - 1/4 Section NW Section 16 Township 7N Range 6W 3. OWNER AT TIME OF DRILLING Mike Houser

OR - Grid or street no. Street name ADDRESS R 4

AND - If available subdivision name, lot & block no. POST OFFICE Prairie du Chien, Wis. 53821

4. Distance in feet from well to nearest: BUILDING 10' SANITARY SEWER C.I. 22' FLOOR DRAIN C.I. 22' FOUNDATION DRAIN SEWER CONNECTED INDEPENDENT WASTE WATER DRAIN C.I. TILE

CLEAR WATER DRAIN C.I. TILE 60' SEPTIC TANK PRIVY SEEPAGE PIT ABSORPTION FIELD 70' BARN SILO ABANDONED WELL SINK HOLE

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Country home

6. DRILLHOLE						9. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
10	Surface	91	6	91	120	Clay	Surface	40	
						loose stone & clay	40	75	
						soft sandstone	75	80	
						hard sandstone	80	120	

7. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	new black steel plain end 19.18	Surface	91

8. GROUT OR OTHER SEALING MATERIAL			10. TYPE OF DRILLING MACHINE USED		
Kind	From (ft.)	To (ft.)	<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Direct Rotary	<input type="checkbox"/> Reverse Rotary
Clay	Surface	40	<input type="checkbox"/> Rotary - air w/drilling mud	<input checked="" type="checkbox"/> Rotary - hammer with drilling mud & air	<input type="checkbox"/> Jetting with <input type="checkbox"/> Air <input type="checkbox"/> Water
Cement	40	91	Well construction completed on <u>3-24-1973</u>		

11. MISCELLANEOUS DATA
Yield test: 3 Hrs. at 6 GPM
Depth from surface to normal water level 100 ft.
Depth to water level when pumping 100 ft.
Well is terminated 10 inches above below final grade
Well disinfected upon completion Yes No
Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 4-2-1973

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Benneth Copian Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 84 Boscobel Wis., 53805

Please do not write in space below

COLIFORM TEST RESULT	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
443				