

WELL CONSTRUCTOR'S REPORT TO WISCONSIN STATE BOARD OF HEALTH
See Instructions on Reverse Side

APR 12 1948

1. County Crawford Town Prairie Du Chemin
 Sec. 18 Village
City Check one and give name Lots 3 + 4

2. Location Lot #3 Sec 18 Town 7 Range 6 Lot #4 Sec 18 Town 7 Range 6.
 T7N R6W S.W. corner, west St Jacques in lot # 70. 18. 7 - 6
 Name of street and number of premises or Sec. Tn. and R. numbers

3. Owner or Agent Dr Disler
 Individual, partnership or firm

4. Mail Address Prairie Du Chemin Wisconsin
 Complete address required

5. From well to nearest: Building 5 ft; sewer none ft; drain none ft; septic tank none ft;
 dry well or filter bed 100 ft; abandoned well 75 ft.

6. Well is intended to supply water for: Summer resort

7. DRILLHOLE:

Dia. (in.)	From (ft.)	To (ft.)
<u>6 1/4</u>	<u>0</u>	<u>86</u>
<u>5</u>	<u>86</u>	<u>100</u>

10. FORMATIONS:

Kind	Thickness	
	From (ft.)	To (ft.)
<u>Black</u>	<u>6</u>	<u>6</u>
<u>Gravel</u>	<u>46</u>	<u>52</u>
<u>Running sand</u>	<u>82</u>	

8. CASING AND LINER PIPE OR CURBING:

Dia. (in.)	Kind	From (ft.)	To (ft.)
<u>5 3/4</u>	<u>Black standard weight steel pipe</u>	<u>0</u>	<u>82</u>

9. GROUT:

Kind	From (ft.)	To (ft.)
<u>puddled clay fill</u>		<u>40</u>

11. MISCELLANEOUS DATA:

Yield test: _____ Hrs. at _____ GPM.

Depth from surface to water: 55 ft.

Water-level when pumping: 60 ft.

Water sample sent to laboratory at La Crosse on Mar 26 1948
00000 3-26-48 # 1931

Signature Fred W. Schultz
 Registered Well Driller

Construction of the well was completed on 27 Mar 1948

The well is terminated _____ inches
 above, below the permanent ground surface.

Was the well disinfected upon completion?
 Yes _____ No _____

Was the well sealed watertight upon completion?
 Yes No _____

Barbersburg, Ia
 Complete Mail Address

CR
445