

WELL CONSTRUCTOR'S REPORT

Well-6

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

1. COUNTY Crawford CHECK ONE Town Village City NAME Prairie du Chien

2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)
NW 1/4 of Sec. 18 T7N R6W

3. OWNER AT TIME OF DRILLING John J. Boor

4. OWNER'S COMPLETE MAIL ADDRESS R7D Prairie du Chien, Wis. 53821
Cliffwood Drive

5. Distance in feet from well to nearest: BUILDING C.I. TILE 10' 15' SANITARY SEWER C.I. TILE FLOOR DRAIN C.I. TILE FOUNDATION DRAIN SEWER CONNECTED INDEPENDENT WASTE WATER DRAIN C.I. TILE 15'

CLEAR WATER DRAIN C.I. TILE SEPTIC TANK PRIVY 60' SEEPAGE PIT 75' ABSORPTION FIELD BARN SILO ABANDONED WELL SINK HOLE

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

6. Well is intended to supply water for: Country Home

7. DRILLHOLE 10. FORMATIONS

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
<u>6</u>	<u>Surface</u>	<u>140</u>				<u>loose sand</u>	<u>Surface</u>	<u>105</u>
						<u>sandstone</u>	<u>105</u>	<u>140</u>

8. CASING, LINER, CURBING, AND SCREEN

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel plain end 19.18</u>	<u>Surface</u>	<u>128</u>

RECEIVED
SEP 12 1969
Dept. Nat. Res.

9. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Surface</u>		

Well construction completed on 4-20-1969

11. MISCELLANEOUS DATA

Yield test: 6 Hrs. at 10 GPM Well is terminated 12 inches above below final grade

Depth from surface to normal water level 105 ft. Well disinfected upon completion Yes No

Depth to water level when pumping 115 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 9-9-1969

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphrooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Copian Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 84 Boscobel, Wis. 53805

COLIFORM TEST RESULT 446 GAS - 24 HRS. GAS - 48 HRS. CONFIRMED REMARKS