

APR 16 1979

1. COUNTY <i>Crawford</i>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name <i>Prairie du Chien</i>	
2. LOCATION OR - Grid or Street No. Street Name		1/4 Section Section Township Range <i>NE 18 7N 7W</i>		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE <i>Dan Pollack</i>	
AND - If available subdivision name, lot & block No.		ADDRESS <i>RFD</i>		POST OFFICE <i>Prairie du Chien, Wis., 53821</i>	
4. Distance in feet from well to nearest: (Record answer in appropriate block)				Building <i>12</i>	
Street Sewer Other Sewers Foundation Drain Connected to: Sewage Sump Clearwater Sump Septic Tank Holding Tank Sewage Absorption Unit		San. Storm C.I. Other Sewer Sewage Sump Clearwater Dr. C.I. Other		C.I. Sewer Other Sewer C.I. Other C.I. Other	
Privy Pet Waste Pit Pit: Nonconforming Existing Subsurface Pumproom Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit		Well Pump Tank Nonconforming Existing		<i>100'</i>	
Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)					
5. Well is intended to supply water for: <i>Country home</i>			9. FORMATIONS		
6. DRILLHOLE			Kind From (ft.) To (ft.)		
Dia. (in.) From (ft.) To (ft.) Dia. (in.) From (ft.) To (ft.)			<i>Clay</i> Surface 0 25		
<i>10</i> Surface <i>0</i> <i>115</i> <i>6</i> <i>115</i> <i>140</i>			<i>Clay & loose stone</i> 25 60		
			<i>soft sandstone</i> 60 100		
			<i>hard sandstone</i> 100 140		
7. CASING, LINER, CURBING AND SCREEN					
Dia. (in.) Material, Weight, Specification & Method of Assembly From (ft.) To (ft.)					
<i>6</i> <i>new black steel</i> <i>RE. 18.97</i> Surface <i>0</i> <i>115</i>					
<i>A-53</i>					
<i>Valley Steel</i>					
<i>Pitless adaptor</i>					
8. GROUT OR OTHER SEALING MATERIAL			10. TYPE OF DRILLING MACHINE USED		
Kind From (ft.) To (ft.)			<input type="checkbox"/> Cable Tool <input type="checkbox"/> Rotary-hammer w/drilling mud & air <input type="checkbox"/> Jetting with <input type="checkbox"/> Air <input type="checkbox"/> Water		
<i>Clay</i> Surface <i>0</i> <i>8</i>			<input checked="" type="checkbox"/> Rotary-hammer & air <input type="checkbox"/> Reverse Rotary		
<i>Cement</i> <i>8</i> <i>115</i>			Well construction completed on <i>Mar 17 - 19 79</i>		
11. MISCELLANEOUS DATA			Well is terminated <i>10</i> inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below		
Yield Test: <i>2</i> Hrs. at <i>5</i> GPM			Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Depth from surface to normal water level <i>105</i> Ft.			Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Depth of water level when pumping <i>120</i> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No					
Water sample sent to <i>Madison</i>			laboratory on <i>April 9 - 19 79</i>		
Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.					
Signature <i>Kenneth Coplan</i> Registered Well Driller			Complete Mail Address <i>R3 Box 84 Boscobel, Wis. 53805</i>		