

WELL CONSTRUCTOR'S REPORT

DEPARTMENT OF RESOURCE DEVELOPMENT

1. COUNTY CRAWFORD CHECK ONE [X] Town [] Village [] City NAME PRAIRIE DU CHIEN, WIS.

2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.) SEC. 19--TOWN 7N--R. 6W Part of the S.E. 1/4 of S.E. 1/4, Part of Lot 1 in Sec 30 N.E. 1/4

3. OWNER AT TIME OF DRILLING ROD SATER Part of S.E. 1/4 of N.E. 1/4 in 30.

4. OWNER'S COMPLETE MAIL ADDRESS 215 WEST DUNN ST. PRAIRIE DU CHIEN, WIS.

Table with 5 columns: BUILDING, SANITARY SEWER, FLOOR DRAIN, FOUNDATION DRAIN, WASTE WATER DRAIN. Values include 15ft, NONE, NONE, NONE, NONE.

Table with 10 columns: CLEAR WATER DRAIN, SEPTIC TANK, PRIVY, SEEPAGE PIT, ABSORPTION FIELD, BARN, SILO, ABANDONED WELL, SINK HOLE. Values include NONE.

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.) THIS WELL IS ON A HIGH HILL, NO OTHER SOURCE.

6. Well is intended to supply water for: WELL IS USED TO WATER SADDLE HORSES.

7. DRILLHOLE and 10. FORMATIONS table. Drillhole: 10" dia, 0-253ft. Formations: top soil and clay (0-18'), BROWN LIME STONE (18-75'), GREY LIME STONE (75-150'), BLUE SHSLE (150-160'), SAND STONE (160-240'), SHALE (240-248'), GREY LIME STONE (248-253').

8. CASING, LINER, CURBING, AND SCREEN table. 6" dia, PLAIN END STEEL, 0-253ft.

9. GROUT OR OTHER SEALING MATERIAL table. NEAT CEMENT, Surface to 253ft.

Well construction completed on SEPT. 30 19 68

11. MISCELLANEOUS DATA table. Yield test: 4 hrs at 12 GPM. Depth from surface to normal water level: 480 ft. Depth to water level when pumping: 495 ft.

Water sample sent to MADIAON laboratory on: OCT. 16 19 68

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphrooms, access pits, etc., should be given on reverse side.

SIGNATURE Lewis Harris -Registered Well Driller COMPLETE MAIL ADDRESS 327 N. MAIN ST. PRAIRIE DU CHIEN, WIS.

Table with 5 columns: COLIFORM TEST RESULT, GAS - 24 HRS., GAS - 48 HRS., CONFIRMED, REMARKS.