

NOV 7 1980

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Prairie du Chien

2. LOCATION 1/4 Section NW Section 29 Township 7 N Range 6 W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE
OR - Grid or Street No. Street Name ADDRESS James O. Cornford
R1 Box 435

AND - If available subdivision name, lot & block No. POST OFFICE Prairie du Chien, W. 53821

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 10' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewage Sump Clearwater Dr. Sewage Sump Clearwater Sump Clearwater Sump Sewage Absorption Unit 75' Seepage Pit Seepage Bed Seepage Trench

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumphouse Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Country home 9. FORMATIONS

Kind	From (ft.)	To (ft.)
Clay & sandstone	Surface	35
broken limestone	35	145
hard sandstone	145	260

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	Surface	162	6	162	260

7. CASING, LINER, CURBING AND SCREEN
Material, Weight, Specification & Method of Assembly

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	162

new black steel R.E. 18.97 A-53 Kent Steel Pitless adapter

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Clay	Surface	7
Cement	7	162

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with Air Water

Rotary-air w/drilling mud Rotary-hammer & air Reverse Rotary

Rotary-w/drilling mud

Well construction completed on 10 - 28 - 1980

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 5 GPM Well is terminated 10 inches above final grade below

Depth from surface to normal water level 150 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 172 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on Nov 3 1980

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Cornford Registered Well Driller Complete Mail Address Boocobal, W. 53805
R2 Box 4