

WELL CONSTRUCTOR'S REPORT  
FORM 3300-15

JAN 14 1976

NOTE

WHITE COPY - DIVISION'S COPY  
GREEN COPY - DRILLER'S COPY  
YELLOW COPY - OWNER'S COPY

STATE OF WISCONSIN  
DEPARTMENT OF NATURAL RESOURCES  
Box 450  
Madison, Wisconsin 53701

1. COUNTY Crawford CHECK ONE  Town  Village  City NAME Prairie du Chien

2. LOCATION - 1/4 Section SW Section 20 Township 7N Range 6W  
OR - Grid or street no. Street name  
3. OWNER AT TIME OF DRILLING Clarence Ahrens  
ADDRESS R7D

AND - If available subdivision name, lot & block no. POST OFFICE Prairie du Chien Wi 53821

4. Distance in feet from well to nearest:  
(Record answer in appropriate block)

BUILDING	SANITARY SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE WATER DRAIN
	C.I. TILE	C.I. TILE	SEWER CONNECTED INDEPENDENT	C.I. TILE
<u>10'</u>	<u>25'</u>			

CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILLO	ABANDONED WELL	SINK HOLE
C.I. TILE								
	<u>70'</u>			<u>85'</u>	<u>200'</u>	<u>200'</u>		

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Country home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>6</u>	<u>Surface</u>	<u>56</u>			

9. FORMATIONS

Kind	From (ft.)	To (ft.)
<u>loose sand</u>	<u>Surface</u>	<u>50</u>
<u>gravel bed water bearing</u>	<u>50</u>	<u>60</u>

7. CASING, LINER, CURBING, AND SCREEN

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel plain end 18.97 A-53 Valley Steel</u>	<u>Surface</u>	<u>56</u>

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>loose sand</u>	<u>Surface</u>	<u>50</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Direct Rotary  Reverse Rotary  
 Rotary - air w/drilling mud  Rotary - hammer with drilling mud & air  Jetting with  Air  Water

Well construction completed on 12-3-1975

11. MISCELLANEOUS DATA

Yield test: 4 Hrs. at 8 GPM

Well is terminated 12 inches  above  below final grade

Depth from surface to normal water level 30 ft. Well disinfected upon completion  Yes  No

Depth to water level when pumping 30 ft. Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on: 1-12-1976

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coplan Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 84 Boscobel Wi, 53805

Please do not write in space below

COLIFORM TEST RESULT <u>450</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
------------------------------------	---------------	---------------	-----------	---------