

1. COUNTY Crawford	CHECK ONE <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City	NAME Prairie Du Chien
2. LOCATION (Number and Street or ¼ section, section, township and range. Also give subdivision name, lot and block numbers when available.) Part of N. W. ¼ of the S. W. ¼ of Sec. 21 - Town 7 - Range 6 - W. ^{R6W}		
3. OWNER AT TIME OF DRILLING Dale Cipra		

4. OWNER'S COMPLETE MAIL ADDRESS R.F.D. 1 - Prairie Du Chien Wis. - 53821

5. Distance in feet from well to nearest: (Record answer in appropriate block)	BUILDING 8 Ft.	SANITARY SEWER C. I. ?	FLOOR DRAIN TILE	FOUNDATION DRAIN SEWER CONNECTED	WASTE WATER DRAIN C. I.
---	-------------------	---------------------------	---------------------	-------------------------------------	----------------------------

CLEAR WATER DRAIN C. I.	SEPTIC TANK TILE	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
	100 Ft.	none	None	150 Ft.	none	None	None	None

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

none

6. Well is intended to supply water for: House only

7. DRILLHOLE						10. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10 in.	Surface	60	6"	60'	501'	Top soil & yellow clay	Surface	20'
						Brown Lime Stone	20	95
						Blue Shale Hard	95	102
						Brown Lime Stone	102	160
						Sand Stone	160	202
						Brown Lime Stone	202	400
						Grey Lime Stone	400	440
						Jordan Sand Stone	440	501
8. CASING, LINER, CURBING, AND SCREEN								
Dia. (in.)	Kind and Weight		From (ft.)	To (ft.)				
6"	Standard Pipe Steel Plain End 19.45 Per Ft.		Surface	60'				
4"	Liner To Steel Plain End 1 1/2"			415'				
Liner comes up in the 6" casing 15 ft.								
9. GROUT OR OTHER SEALING MATERIAL								
Kind			From (ft.)	To (ft.)				
Neat Cement			Surface	60'				
						Well construction completed on Oct. 21 1968		

11. MISCELLANEOUS DATA	4 Hrs. at 15 GPM	Well is terminated 8 inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade
Yield test:		Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Depth from surface to normal water level	415 ft.	Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Depth to water level when pumping	415 ft.	

Water sample sent to Madison laboratory on: Oct. 29 1968

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphrooms, access pits, etc., should be given on reverse side.

SIGNATURE <i>Lewis Harris</i> Lewis Harris Registered Well Driller	COMPLETE MAIL ADDRESS 327 N. Main St. Prairie Du Chien, Wis. 53821
---	--

Please do not write in space below

COLIFORM TEST RESULT	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
----------------------	---------------	---------------	-----------	---------