

1. COUNTY Crawford CHECK ONE Town Village City NAME Prairie Du Chien
 2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)
Town 7N Range 6W Section 22 S.E. corner of S.W. 1/4 of N.W. 1/4

3. OWNER AT TIME OF DRILLING
Larry Jelinek

4. OWNER'S COMPLETE MAIL ADDRESS
Prairie Du Chien, Wisconsin

5. Distance in feet from well to nearest:
 (Record answer in appropriate block)

BUILDING C.I.	SANITARY SEWER TILE	FLOOR DRAIN C.I.	TILE	FOUNDATION DRAIN SEWER CONNECTED	INDEPENDENT	WASTE WATER DRAIN C.I.	TILE		
8									
CLEAR WATER DRAIN C.I.	TILE	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
		75			100	160			

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

6. Well is intended to supply water for:
Farm

7. DRILLHOLE						10. FORMATIONS		
Dis. (in.)	From (ft.)	To (ft.)	Dis. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	113				Top soil and clay	Surface	10
6	113	580				Brown limestone	10	90

8. CASING, LINER, CURBING, AND SCREEN				10. FORMATIONS		
Dis. (in.)	Kind and Weight	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
6	Steel pipe 19.45	Surface	113	gray limestone	90	145
				1/4 Blue shale	145	150
				Gray limestone	150	193
				St. Peter sandstone	193	235
				Gray limestone	235	515
				Jordan sandstone	515	580

9. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Cement <i>Heat was used</i>	Surface	113

11. MISCELLANEOUS DATA

Yield test: 3 Hrs. at 9 GPM

Well construction completed on 4/7/66 19

Well is terminated 10 inches above below final grade

Depth from surface to normal water level 480 ft. Well disinfected upon completion Yes No

Depth to water level when pumping 493 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 4/12/66 19

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphouses, access pits, etc., should be given on reverse side.

SIGNATURE Duane Lubbers Registered Well Driller COMPLETE MAIL ADDRESS Farmersburg Iowa 52047

Please do not write in space below

COLIFORM TEST RESULT	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
458				