

**WELL CONSTRUCTOR'S REPORT TO WISCONSIN STATE BOARD OF HEALTH**

See Instructions on Reverse Side

1. County Crawford Town  Prairie Du Chien  
 Village  City  Check one and give name

2. Location n.w. 1/4 of n.w. 1/4 of sec 22 Range 6W T7N  
 Name of street and number of premise or Section, Town and Range numbers

3. Owner  or Agent  Vincent Schmidt JUN 23 1959  
 Name of individual, partnership or firm

4. Mail Address Prairie Du Chien Wis ENVIRONMENTAL SANITATION  
 Complete address required

5. From well to nearest: Building 30 ft; sewer \_\_\_\_\_ ft; drain \_\_\_\_\_ ft; septic tank 100 ft;  
 dry well or filter bed 115 ft; abandoned well 50 ft.

6. Well is intended to supply water for: Home and Stock

**7. DRILLHOLE:**

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	0	44	6	44	560

**8. CASING AND LINER PIPE OR CURBING:**

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	Black Pipe	0	44

**9. GROUT:**

Kind	From (ft.)	To (ft.)
Best Cement	8	44

**11. MISCELLANEOUS DATA:**

Yield test: 3 Hrs. at 10 GPM.  
 Depth from surface to water-level: 430 ft.  
 Water-level when pumping: 450 ft.  
 Water sample was sent to the state laboratory at:  
 \_\_\_\_\_ on \_\_\_\_\_ 19\_\_\_\_  
 City

**10. FORMATIONS:**

Kind	From (ft.)	To (ft.)
Surface and Clay	0	5
Clay and Boulders	5	20
Galena Limestone	20	45
Platteville	45	145
Linton Limestone	145	184
St. Peter Sandstone	184	225
Magnesian	225	545
Diamond Sandstone	545	560

Construction of the well was completed on:  
June 3 1959

The well is terminated 10 inches  
 above, below  the permanent ground surface.

Was the well disinfected upon completion?  
 Yes  No \_\_\_\_\_

Was the well sealed watertight upon completion?  
 Yes  No \_\_\_\_\_

Signature Tony Burt Registered Well Driller Box 503 Cuba City Wis Complete Mail Address  
 Please do not write in space below

Rec'd JUN 11 1959 16713  
 Ans'd \_\_\_\_\_  
 Interpretation SAFE

10 ml 10 ml 10 ml 10 ml 10 ml  
 Gas—24 hrs. \_\_\_\_\_  
 48 hrs. \_\_\_\_\_  
 Confirm \_\_\_\_\_  
 B. Coll [Signature]  
 Examiner \_\_\_\_\_