

NOTE:

White Copy - Division's Copy  
 Green Copy - Driller's Copy  
 Yellow Copy - Owner's Copy

JUN 17 1977  
 WELLS CONSTRUCTOR'S REPORT  
 Form 3300-15  
 Rev. 10-75

1. COUNTY <b>Crawford</b>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name <b>Prairie du Chien</b>	
2. LOCATION 1/4 Section <b>SW</b> Section <b>23</b> OR - Grid or Street No.    Street Name		Township <b>7N</b> Range <b>6W</b>		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE <b>Floyd Clark</b>	
AND - If available subdivision name, lot & block No.		ADDRESS <b>RFD</b>		POST OFFICE <b>Prairie du Chien, Wis. 53821</b>	
4. Distance in feet from well to nearest: (Record answer in appropriate block)		Building <b>12'</b>		Sanitary Bldg. Drain C.I. <b>25'</b> Other	
		Sanitary Bldg. Sewer C.I.		Floor Drain Connected To: C.I. Sewer    Other Sewer	
		Storm Bldg. Drain C.I.		Storm Bldg. Sewer C.I.    Other	
		Street Sewer San.    Storm		Sewage Absorption Unit <b>75'</b> Seepage Pit Seepage Bed Seepage Trench	
Privy    Pet Waste Pit		Foundation Drain Connected to: Sewer    Sewage Sump    Clearwater Dr.		Sewage Sump    Clearwater Sump    Septic Tank <b>60'</b> Holding Tank	
Pit: Nonconforming Existing Well    Pump    Tank		Subsurface Pumproom Nonconforming Existing		Barn Gutter    Animal Barn Pen    Animal Yard    Silo With Pit    Glass Lined Storage Facility    Silo w/o Pit    Earthen Silage Storage Trench Or Pit	
Temporary Manure Stack		Watertight Liquid Manure Tank		Solid Manure Storage Structure	
		Subsurface Gasoline or Oil Tank		Waste Pond or Land Disposal Unit (Specify Type)	
				Other (Give Description)	
5. Well is intended to supply water for: <b>Country home</b>			9. FORMATIONS		
6. DRILLHOLE			Kind		
Dia. (in.)    From (ft.)    To (ft.)    Dia. (in.)    From (ft.)    To (ft.)			From (ft.)    To (ft.)		
<b>10    Surface    65    6    65    100</b>			<b>loose stone &amp; clay    Surface<sup>0</sup>    40</b>		
			<b>limestone    40    100</b>		
7. CASING, LINER, CURBING AND SCREEN Material, Weight, Specification & Method of Assembly			Dia. (in.)    From (ft.)    To (ft.)		
<b>6    new black steel    Surface    65</b>					
<b>P.E. 18.97</b>					
<b>A-53</b>					
<b>Valley Steel</b>					
<b>Pitless adaptor</b>					
8. GROUT OR OTHER SEALING MATERIAL			10. TYPE OF DRILLING MACHINE USED		
Kind    From (ft.)    To (ft.)			<input type="checkbox"/> Cable Tool <input type="checkbox"/> Rotary-hammer w/drilling mud & air <input type="checkbox"/> Jetting with <input type="checkbox"/> Rotary-air w/drilling mud <input checked="" type="checkbox"/> Rotary-hammer & air <input type="checkbox"/> Air <input type="checkbox"/> Rotary-w/drilling mud <input type="checkbox"/> Reverse Rotary <input type="checkbox"/> Water		
<b>Clay    Surface    7</b>					
<b>Cement    7    65</b>			Well construction completed on <b>5-30-1977</b>		
11. MISCELLANEOUS DATA			Well is terminated <b>10</b> inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below		
Yield Test: <b>3</b> Hrs. at <b>5</b> GPM			Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Depth from surface to normal water level <b>45</b> Ft.			Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Depth of water level when pumping <b>52</b> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No					
Water sample sent to <b>Madison</b> laboratory on <b>6-13-1977</b>					

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature  
**Kenneth Coplan** Registered Well Driller

Complete Mail Address  
**R3 Box 84    Boscobel, Wis. 53805**