

SEP - 5 1972

WELL CONSTRUCTOR'S REPORT  
FORM 3300-15

STATE OF WISCONSIN  
DEPARTMENT OF NATURAL RESOURCES  
Box 450  
Madison, Wisconsin 53701

**NOTE**  
WHITE COPY - DIVISION'S COPY  
GREEN COPY - DRILLER'S COPY  
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford		CHECK ONE <input type="checkbox"/> Town <input type="checkbox"/> Village <input checked="" type="checkbox"/> City			NAME Praire Du Chien	
2. LOCATION - 1/4 Section SE 1/4 SW 1/4		Section 26	Township 7 N	Range 6 W	3. OWNER AT TIME OF DRILLING Clement Mezera	
OR - Grid or street no.		Street name			ADDRESS Rte. 2	
AND - If available subdivision name, lot & block no.					POST OFFICE Praire Du Chien, Wisc.	
4. Distance in feet from well to nearest: (Record answer in appropriate block)		BUILDING 4	SANITARY SEWER C.I. --- TILE ---	FLOOR DRAIN C.I. --- TILE ---	FOUNDATION DRAIN SEWER CONNECTED INDEPENDENT None	WASTE WATER DRAIN C.I. --- TILE ---
CLEAR WATER DRAIN C.I. --- TILE ---	SEPTIC TANK ---	PRIVY 160	SEEPAGE PIT None	ABSORPTION FIELD ---	BARN 65	SILO ---
ABANDONED WELL ---	SINK HOLE ---					

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

None

5. Well is intended to supply water for:  
Grade B Dairy Farm & House

6. DRILLHOLE						9. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	61	6	61	452	Clay	Surface	12
						Soft Brn. Limestone	12	48
7. CASING, LINER, CURBING, AND SCREEN						Hard Brn. Limestone		
Dia. (in.)	Kind and Weight		From (ft.)	To (ft.)			48	61
6	New Steel P. E.		Surface	61		Recasing Job		
	18.97# per ft.					No other samples available		

8. GROUT OR OTHER SEALING MATERIAL			10. TYPE OF DRILLING MACHINE USED		
Kind	From (ft.)	To (ft.)	<input checked="" type="checkbox"/> Cable Tool	<input type="checkbox"/> Direct Rotary	<input type="checkbox"/> Reverse Rotary
Neat cement grout	Surface	61	<input type="checkbox"/> Rotary - air w/drilling mud	<input type="checkbox"/> Rotary - hammer with drilling mud & air	<input type="checkbox"/> Jetting with <input type="checkbox"/> Air <input type="checkbox"/> Water
			Well construction completed on 8-21 1972		

11. MISCELLANEOUS DATA			Well is terminated 26 inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade		
Yield test:	4	Hrs. at 14	GPM		
Depth from surface to normal water level	390	ft.		Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Depth to water level when pumping	420	ft.		Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	

Water sample sent to State Lab. of Hygiene ; Madison, Wisc. laboratory on: 8-29 1972

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE <i>Duane Lubbers</i> Duane Lubbers		W.D. 410 Registered Well Driller		COMPLETE MAIL ADDRESS Duane Lubbers Farmersburg, Iowa 52047	
--	--	-------------------------------------	--	---	--

Please do not write in space below

COLIFORM TEST RESULT 465	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
-----------------------------	---------------	---------------	-----------	---------