

NOTE:

White Copy - Division's Copy  
 Green Copy - Driller's Copy  
 Yellow Copy - Owner's Copy

NOV 14 1978

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Name Prairie du Chien

2. LOCATION 1/4 Section NW Section 27 Township 7N Range 7W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE

OR - Grid or Street No. Street Name ADDRESS Paul adney  
RFD

AND - If available subdivision name, lot & block No. POST OFFICE Prairie du Chien W. 5382

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 20'

Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer	
C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other

Street Sewer		Other Sewers		Foundation Drain Connected to:		Sewage Sump		Clearwater Sump		Septic Tank		Holding Tank		Sewage Absorption Unit	
San.	Storm	C.I.	Other	Sewer	Clearwater Dr.	Sewage Sump	Clearwater Sump	C.I.	Other	Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit	Seepage Pit	Seepage Bed

Privy	Pet Waste Pit	Pit: Nonconforming Existing	Subsurface Pumproom	Barn Gutter	Animal Barn Pen	Animal Yard	Silo With Pit	Glass Lined Storage Facility	Silo w/o Pit	Earthen Silage Storage Trench Or Pit
-------	---------------	-----------------------------	---------------------	-------------	-----------------	-------------	---------------	------------------------------	--------------	--------------------------------------

Temporary Manure Stack	Watertight Liquid Manure Tank	Solid Manure Storage Structure	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Other (Give Description)
------------------------	-------------------------------	--------------------------------	---------------------------------	---	--------------------------

5. Well is intended to supply water for: Trailer home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	Surface	160	6	160	260

9. FORMATIONS

Kind	From (ft.)	To (ft.)
Clay	Surface	8
Clay & loose stone	8	25
broken limestone	25	145
hard limestone	145	260

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
6	new black steel R.E 18.97 A-53 Valley Steel Pitless adaptor	Surface	160

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Clay	Surface	7
Cement	7	160

10. TYPE OF DRILLING MACHINE USED

<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Rotary-hammer w/drilling mud & air	<input type="checkbox"/> Jetting with
<input type="checkbox"/> Rotary-air w/drilling mud	<input checked="" type="checkbox"/> Rotary-hammer & air	<input type="checkbox"/> Air
<input type="checkbox"/> Rotary-w/drilling mud	<input type="checkbox"/> Reverse Rotary	<input type="checkbox"/> Water

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 5 GPM

Depth from surface to normal water level 180 Ft.

Depth of water level when pumping 186 Ft. Stabilized  Yes  No

Well construction completed on 10 - 23 - 1978

Well is terminated 10 inches  above  below final grade

Well disinfected upon completion  Yes  No

Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on 11 - 8 - 1978

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Coplan Registered Well Driller Complete Mail Address Boscobel, Wisc. R3 Box 84 53805