

JUL 03 1973

27728

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

NOTE
WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE Town Village City NAME Bridgeport

2. LOCATION - 1/4 Section SW Section 32 Township 6-7N Range 6-7W

OR - Grid or street no. Street name T 7N R 6W?

AND - If available subdivision name, lot & block no.

3. OWNER AT TIME OF DRILLING Donald F. Chaney
ADDRESS R 7D Prairie du Chien
POST OFFICE Wis., 53821

4. Distance in feet from well to nearest:

BUILDING C. I.	SANITARY SEWER TILE	FLOOR DRAIN C. I.	FOUNDATION DRAIN SEWER CONNECTED	FOUNDATION DRAIN INDEPENDENT	WASTE WATER DRAIN C. I.	WASTE WATER DRAIN TILE
<u>10'</u>	<u>20'</u>	<u>20'</u>				

(Record answer in appropriate block)

CLEAR WATER DRAIN C. I.	CLEAR WATER DRAIN TILE	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
		<u>90'</u>			<u>125'</u>				

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Country home

6. DRILLHOLE						9. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
<u>10</u>	<u>Surface</u>	<u>47</u>	<u>6</u>	<u>47</u>	<u>160</u>	<u>Clay</u>	<u>Surface</u>	<u>20</u>	
						<u>loose rock</u>	<u>20</u>	<u>40</u>	
						<u>limestone</u>	<u>40</u>	<u>90</u>	
						<u>sandstone</u>	<u>90</u>	<u>160</u>	

7. CASING, LINER, CURBING, AND SCREEN

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel plain end 19.18</u>	<u>Surface</u>	<u>47</u>

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>20</u>
<u>Cement</u>	<u>20</u>	<u>47</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool Direct Rotary Reverse Rotary

Rotary - air w/drilling mud Rotary - hammer with drilling mud & air Jetting with Air Water

11. MISCELLANEOUS DATA

Yield test: 3 Hrs. at 9 GPM

Depth from surface to normal water level 123 ft.

Depth to water level when pumping 138 ft.

Well construction completed on 5-26-1973

Well is terminated 10 inches above below final grade

Well disinfected upon completion Yes No

Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 6-28-1973

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Corpien Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 84 Boscobel Wis., 53805

Please do not write in space below

COLIFORM TEST RESULT <u>474</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
------------------------------------	---------------	---------------	-----------	---------