

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Name Bridgeport

2. LOCATION SE 32 Township 7N Range 6W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE  
ADDRESS McHegge Lumber  
McHegge  
POST OFFICE Luwa

AND - If available subdivision name, lot & block No.

4. Distance in feet from well to nearest: (Record answer in appropriate block)

Building	Sanitary Bldg. Drain	Sanitary Bldg. Sewer	Floor Drain Connected To:	Storm Bldg. Drain	Storm Bldg. Sewer
<u>110</u>	C.I. Other	C.I. Other	C.I. Sewer Other Sewer	C.I. Other	C.I. Other

Street Sewer	Other Sewers	Foundation Drain Connected to:	Sewage Sump	Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit
San. Storm C.I. Other	Sewer	Sewage Sump Clearwater Dr.	C.I. Other				Seepage Pit Seepage Bed Seepage Trench
							<u>150</u> <u>150</u>

Privy	Pet Waste Pit	Pit: Nonconforming Existing	Subsurface Pumproom	Barn Gutter	Animal Barn Pen	Animal Yard	Silo With Pit	Glass Lined Storage Facility	Silo w/o Pit	Earthen Silage Storage Trench Or Pit
		Well Pump Tank	Nonconforming Existing							

Temporary Manure Stack	Watertight Liquid Manure Tank	Solid Manure Storage Structure	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Other (Give Description)

5. Well is intended to supply water for: Home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>42</u>			
<u>6</u>	<u>42</u>	<u>464</u>			

9. FORMATIONS

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>23</u>
<u>Mag lime</u>	<u>23</u>	<u>275</u>
<u>Carbonaceous Sand</u>	<u>275</u>	<u>360</u>
<u>Galeburg Dolomite</u>	<u>360</u>	<u>464</u>

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
<u>6"</u>	<u>New Steel to C 19.45</u>	<u>Surface</u>	<u>42</u>
	<u>A 53 Greenpoint</u>		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Cement</u>	<u>Surface</u>	<u>42</u>

10. TYPE OF DRILLING MACHINE USED

<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Rotary-hammer w/drilling mud & air	<input type="checkbox"/> Jetting with
<input type="checkbox"/> Rotary-air w/drilling mud	<input checked="" type="checkbox"/> Rotary-hammer & air	<input type="checkbox"/> Air
<input type="checkbox"/> Rotary-w/drilling mud	<input type="checkbox"/> Reverse Rotary	<input type="checkbox"/> Water

Well construction completed on 10-25-78

11. MISCELLANEOUS DATA

Yield Test: 2 Hrs. at 40 GPM

Depth from surface to normal water level 305 Ft.

Depth of water level when pumping 360 Ft. Stabilized  Yes  No

Well is terminated 8 inches  above  below final grade

Well disinfected upon completion  Yes  No

Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on Nov 14 1979

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Ralph J. Faherty  
Registered Well Driller

Complete Mail Address **Faherty Drilling Co., Inc.**  
1120 Broadway P.O. Box 408  
Platteville, Wisconsin 53888