

NOTE:

White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

JUN 12 1979

1. COUNTY Crawford		CHECK (A) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name Bridgport	
2. LOCATION OR - Grid or Street No. Street Name		Section SE 32		Township Range T N 6 W	
AND - If available subdivision name, lot & block No.		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (A) ONE McGregor Lumber Co			
4. Distance in feet from well to nearest: (Record answer in appropriate block)		Building		POST OFFICE McGregor, Iowa	
		Sanitary Bldg. Drain C.I. Other		Sanitary Bldg. Sewer C.I. Other	
		Floor Drain Connected to: C.I. Sewer Other Sewer		Storm Bldg. Drain C.I. Other	
		Storm Bldg. Sewer C.I. Other			
Street Sewer		Other Sewers		Foundation Drain Connected to:	
San. Storm C.I. Other		Sewer		Sewage Sump C.I. Other	
		Clearwater Dr.		Clearwater Sump	
Privy		Pet Waste Pit		Septic Tank	
		Pit: Nonconforming Existing		Holding Tank	
		Well Pump Tank		Sewage Absorption Unit Seepage Pit Seepage Bed Seepage Trench	
Temporary Manure Stack		Watertight Liquid Manure Tank		Sewage Sump	
		Solid Manure Storage Structure		Clearwater Sump	
		Subsurface Gasoline or Oil Tank		Sewage Sump	
		Waste Pond or Land Disposal Unit (Specify Type)		Septic Tank	
				Holding Tank	
				Sewage Absorption Unit	
				Seepage Pit	
				Seepage Bed	
				Seepage Trench	
				Silo w/o Pit	
				Earthen Silage Storage Trench Or Pit	
				Glass Lined Storage Facility	
				Animal Barn Pen	
				Animal Yard	
				Silo With Pit	
				Barn Gutter	
				Subsurface Pumproom	
				Nonconforming Existing	
				Other (Give Description)	
5. Well is intended to supply water for: None		9. FORMATIONS			
6. DRILLHOLE		Kind		From (ft.) To (ft.)	
Dia. (in.) From (ft.) To (ft.)		Clay		Surface 12	
10 Surface 148		Blue Rock		12 22	
6 148 544		Oil rock		22 35	
7. CASING, LINER, CURBING AND SCREEN		Trenton Lime		35 90	
Material, Weight, Specification & Method of Assembly		St Peter		90 130	
Dia. (in.) From (ft.) To (ft.)		May lime		130 400	
6" New steel T & C 19.45 Surface 148		Cambrian sand		400 440	
A-53 youngstown		Halesburg Dolomite		440 544	
8. GROUT OR OTHER SEALING MATERIAL		10. TYPE OF DRILLING MACHINE USED			
Kind From (ft.) To (ft.)		<input type="checkbox"/> Cable Tool <input type="checkbox"/> Rotary-hammer w/drilling mud & air <input type="checkbox"/> Jetting with			
Cement Surface 148		<input type="checkbox"/> Rotary-air w/drilling mud <input checked="" type="checkbox"/> Rotary-hammer <input type="checkbox"/> Air			
		<input type="checkbox"/> Rotary-w/drilling mud <input type="checkbox"/> Reverse Rotary <input type="checkbox"/> Water			
		Well construction completed on 11-15-1978			
11. MISCELLANEOUS DATA		Well is terminated 8 inches <input type="checkbox"/> above final grade <input type="checkbox"/> below			
Yield Test: 2 Hrs. at 40 GPM		Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Depth from surface to normal water level 390 Ft.		Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Depth of water level when pumping 430 Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Water sample sent to Madison laboratory on June 5-1979			
Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.					
Signature Ralph J. Faherty Registered Well Driller			Complete Mail Address Faherty Drilling Co., Inc. 1120 Broadway P.O. Box 409 Platteville, Wisconsin 53818		

476