

# WELL CONSTRUCTOR'S REPORT

Well-6

WHITE COPY - DIVISION'S COPY  
 GREEN COPY - DRILLER'S COPY  
 YELLOW COPY - OWNER'S COPY

STATE OF WISCONSIN  
 DEPARTMENT OF NATURAL RESOURCES  
 Box 450  
 Madison, Wisconsin 53701

1. COUNTY Crawford CHECK ONE  Town  Village  City NAME Bridgeport

2. LOCATION (Number and Subst or 1/4 section, township and range. Also give subdivision name, lot and block numbers when available.)  
SW 1/4 of Sec. 35 T 7N R 6W

3. OWNER AT TIME OF DRILLING William Balk

4. OWNER'S COMPLETE MAIL ADDRESS R.F.D. Prairie du Chien, Wis. 53821

5. Distance in feet from well to nearest: (Record answer in appropriate block)

BUILDING	SANITARY SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE WATER DRAIN
C. I.	C. I.	C. I.	SEWER CONNECTED	INDEPENDENT
TILE	TILE	TILE	C. I.	TILE
8'	15'	15'		

CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
C. I.	TILE							
	65'			100'				

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

6. Well is intended to supply water for: Home

7. DRILLHOLE						10. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	55	6	55	180	Clay	Surface	45
						limestone	45	120
						sandstone	120	180

8. CASING, LINER, CURBING, AND SCREEN

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	new black steel plain end 19.18	Surface	55

9. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Clay	Surface	45
Cement	45	55

11. MISCELLANEOUS DATA

Yield test: 5 Hrs. at 12 GPM

Depth from surface to normal water level 150 ft.

Depth to water level when pumping 150 ft.

Well construction completed on 8-26-1969

Well is terminated 12 inches  above  below final grade

Well disinfected upon completion  Yes  No

Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on: 9-9-1969

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Copian Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 84 Boscobel Wis. 53805

Please do not write in space below

COLIFORM TEST RESULT 488	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
-----------------------------	---------------	---------------	-----------	---------