

OCT 12 1972

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

1106a

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

NOTE
WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE Town Village City NAME Marietta

2. LOCATION - 1/4 Section NW Section 1 Township 7N Range 3W
OR - Grid or street no. Street name 9
3. OWNER AT TIME OF DRILLING Mr. John Eadie
ADDRESS R7D

AND - If available subdivision name, lot & block no. POST OFFICE Boscobel 53805

4. Distance in feet from well to nearest:
(Record answer in appropriate block)

BUILDING C. I.	SANITARY SEWER TILE	FLOOR DRAIN C. I.	FOUNDATION DRAIN SEWER CONNECTED	FOUNDATION DRAIN INDEPENDENT	WASTE WATER DRAIN C. I.	WASTE WATER DRAIN TILE
<u>6'</u>	<u>50'</u>				<u>50'</u>	

CLEAR WATER DRAIN C. I.	CLEAR WATER DRAIN TILE	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
		<u>50'</u>			<u>65'</u>				

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Country home

6. DRILLHOLE						9. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
<u>10</u>	<u>Surface</u>	<u>165</u>	<u>6</u>	<u>165</u>	<u>385</u>	<u>Clay</u>	<u>Surface</u>	<u>15</u>	
						<u>soft sandstone</u>	<u>15</u>	<u>25</u>	
						<u>limestone</u>	<u>25</u>	<u>285</u>	
						<u>blue limestone</u>	<u>285</u>	<u>300</u>	
						<u>sandstone</u>	<u>300</u>	<u>385</u>	

7. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel plain end 19.18</u>	<u>Surface</u>	<u>165</u>

8. GROUT OR OTHER SEALING MATERIAL			10. TYPE OF DRILLING MACHINE USED		
Kind	From (ft.)	To (ft.)	<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Direct Rotary	<input type="checkbox"/> Reverse Rotary
<u>Clay</u>	<u>Surface</u>	<u>15</u>	<input type="checkbox"/> Rotary - air w/drilling mud	<input checked="" type="checkbox"/> Rotary - hammer with drilling mud & air	<input type="checkbox"/> Jetting with <input type="checkbox"/> Air <input type="checkbox"/> Water
<u>Cement</u>	<u>15</u>	<u>165</u>	Well construction completed on <u>9-20-1972</u>		

11. MISCELLANEOUS DATA
Yield test: 2 Hrs. at 6 GPM
Well is terminated 10 inches above below final grade
Depth from surface to normal water level 300 ft. Well disinfected upon completion Yes No
Depth to water level when pumping 310 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 10-9-1972

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Copian Registered Well Driller COMPLETE MAIL ADDRESS Boscobel R3 Box 84 Hwy, 53805
Please do not write in space below

COLIFORM TEST RESULT <u>499</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
------------------------------------	---------------	---------------	-----------	---------