

NOV 22 1972

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

11081 ✓
STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

NOTE

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE Town Village City NAME Marietta

2. LOCATION - 1/4 Section NE Section 2 Township 8N Range 3W
OR - Grid or street no. Street name
3. OWNER AT TIME OF DRILLING Windward Farms
ADDRESS R7D

AND - If available subdivision name, lot & block no. POST OFFICE Boscobel, Wis., 53805

4. Distance in feet from well to nearest:
(Record answer in appropriate block)

BUILDING	SANITARY SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE WATER DRAIN
<u>10'</u>	C. I. TILE	C. I. TILE	SEWER CONNECTED INDEPENDENT	C. I. TILE

CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILLO	ABANDONED WELL	SINK HOLE
C. I. TILE					<u>50'</u>			

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Feeding lot

6. DRILLHOLE						9. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
<u>10</u>	<u>Surface</u>	<u>85</u>	<u>6</u>	<u>85</u>	<u>440</u>	<u>Clay</u>	<u>Surface</u>	<u>20</u>	
						<u>loose stone & clay</u>	<u>20</u>	<u>70</u>	
						<u>limestone</u>	<u>70</u>	<u>210</u>	
						<u>sandstone</u>	<u>210</u>	<u>280</u>	
						<u>hard shale stone</u>	<u>280</u>	<u>440</u>	

7. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel plain end 19.18</u>	<u>Surface</u>	<u>85</u>

8. GROUT OR OTHER SEALING MATERIAL			10. TYPE OF DRILLING MACHINE USED		
Kind	From (ft.)	To (ft.)	<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Direct Rotary	<input type="checkbox"/> Reverse Rotary
<u>Clay</u>	<u>Surface</u>	<u>20</u>	<input type="checkbox"/> Rotary - air w/drilling mud	<input checked="" type="checkbox"/> Rotary - hammer with drilling mud & air	<input type="checkbox"/> Jetting with <input type="checkbox"/> Air <input type="checkbox"/> Water
<u>Cement</u>	<u>20</u>	<u>85</u>	Well construction completed on <u>11-16-1972</u>		

11. MISCELLANEOUS DATA
Yield test: 4 Hrs. at 8 GPM
Well is terminated 10 inches above below final grade
Depth from surface to normal water level 360 ft. Well disinfected upon completion Yes No
Depth to water level when pumping 370 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 11-20-1972

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Cyprian Registered Well Driller COMPLETE MAIL ADDRESS Boscobel R3 Box 84 Wis., 53805
Please do not write in space below

COLIFORM TEST RESULT <u>501</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
REV. 3-71				