

SEP 24 1970

WELL CONSTRUCTOR'S REPORT

Well-6

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

1. COUNTY Crawford CHECK ONE Town Village City NAME Marietta

2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)
NW 1/4 of Sec. 4 T9N R3W

3. OWNER AT TIME OF DRILLING Gordon Clark

4. OWNER'S COMPLETE MAIL ADDRESS R78 Boscobel, Wis., 53805

5. Distance in feet from well to nearest: (Record answer in appropriate block)		BUILDING C.I.	SANITARY SEWER TILE	FLOOR DRAIN C.I.	FLOOR DRAIN TILE	FOUNDATION DRAIN SEWER CONNECTED	FOUNDATION DRAIN INDEPENDENT	WASTE WATER DRAIN C.I.	WASTE WATER DRAIN TILE
		60'	70'		70'				
CLEAR WATER DRAIN C.I.	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE	
				90'	200'				

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

6. Well is intended to supply water for: Farm home

7. DRILLHOLE						10. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	91	6	91	360	Clay	Surface	60
						limestone	60	91

8. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	new black steel plain ends 19.18	Surface	91
beyond this I do not know as this was a recase job.			

9. GROUT OR OTHER SEALING MATERIAL		
Kind	From (ft.)	To (ft.)
Clay	Surface	60
Cement	60	91

11. MISCELLANEOUS DATA

Yield test: 3 Hrs. at 15 GPM

Well construction completed on 7-10-1970

Well is terminated 11 inches above below final grade

Depth from surface to normal water level 298 ft. Well disinfected upon completion Yes No

Depth to water level when pumping 310 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 9-21-1970

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphrooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coplan Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 84 Boscobel, Wis., 53805

Please do not write in space below

COLIFORM TEST RESULT	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
503				