

**First Water Quality Test For
WISCONSIN UNIQUE WELL NUMBER BA 671**

State of Wisconsin
Department of Natural Resources
Private Water Supply - WS/2
Box 7921
Madison, WI 53707

Property Owner Pat Brown Telephone Number (608) 375-5683
Mailing Address R.R. 2 Box 167
City Boscobel State WI Zip Code 53805
County Crawford County Well Location Permit No. W Well Completion Date 6/21/89

JUL 18 1989
1. Location (Please type or print using a black pen.)
 Town City Village Fire # (if available)
of Marietta
Grid or Street Address or Road Name and Number (if available)
Subdivision Name Lot # Block #

Well Constructor (Business Name) Registration #
Corpin Well Drilling Inc 75
Address
501 E. DAK ST.
City Boscobel State WI Zip Code 53805

2. Mark well location in correct 40-acre parcel of section.
N
W E
S

Gov't Lot 15 or SW 1/4 of NW 1/4 of Section 15; T N; R W

3. Well Type New T8N R3W?
 Replacement Reconstruction/Rehabilitation

of well constructed in 19 ____.
Reason for new, reconstructed, replaced, or rehabilitated well?
New trailer
 Drilled Driven Point Jetted Other

4. Well serves 4 of homes and/or
(ex: barn, restaurant, church, school, industry, etc.)
High Capacity Well? Yes No
High Capacity Property? Yes No

5. Well Located on Highest Point of Property, Consistent with the General Layout and Surroundings? Yes No
Well Located in Floodplain? Yes No
Distance In Feet From Well To Nearest:
1. Landfill
20 2. Building Overhang
70 3. Septic or Holding Tank
120 4. Sewage Absorption Unit outside faucet
5. Nonconforming Pit
6. Buried Home Heating Oil Tank
7. Buried Petroleum Tank
8. Shoreline/Swimming Pool
9. Downspout/Yard Hydrant
10. Privy
11. Foundation Drain to Clearwater
12. Foundation Drain to Sewer
 Cast Iron or Plastic Other
13. Building Drain
 Cast Iron or Plastic Other
14. Building Sewer Gravity Pressure
 Cast Iron or Plastic Other
15. Collector Sewer
16. Clearwater Sump
17. Wastewater Sump
18. Paved Animal Barn Pen
19. Animal Yard or Shelter
20. Silo - Type
21. Barn Gutter
22. Manure Pipe Gravity Pressure
 Cast Iron or Plastic Other
23. Other Manure Storage
Other NR 112 Waste Source
24.

6. Drillhole Dimensions

Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>surface</u>	<u>79</u>
<u>6</u>	<u>79</u>	<u>120</u>

Method of constructing upper enlarged drillhole. (If applicable more than one.)
 1. Rotary - Mud Circulation
 2. Rotary - Air
 3. Rotary - Foam
 4. Reverse Rotary
 5. Cable-tool Bit ____ in. dia.
 6. Temp. Outer Casing 10 in. dia. Removed? Yes No
 7. Other

9. Geology

Type, Caving/Noncaving, Color, Hardness, Etc.	From (ft.)	To (ft.)
<u>DIRT</u>	<u>surface</u>	<u>9</u>
<u>CB Clay + Loose rock</u>	<u>9</u>	<u>32</u>
<u>SH Soft Shale</u>	<u>32</u>	<u>74</u>
<u>HH Hard Shale</u>	<u>74</u>	<u>115</u>
<u>IN White sand rock</u>	<u>115</u>	<u>120</u>

7. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Mfg. & Method of Assembly	From (ft.)	To (ft.)
<u>6</u>	<u>New Black Steel Plain End</u>	<u>surface</u>	<u>79</u>
	<u>ERW ASTM A-53A #18.97 6x2-1</u>		

10. Static Water Level
5 ft. above ground level
5 ft. below ground surface

11. Pump Test
Pumping Level 88 ft. below surface
Pumping at 7 GPM for 2 hours

12. Well Is:
 Above Grade
 Below Grade
Developed? Yes No
Disinfected? Yes No
Capped? Yes No

8. Grout or Other Sealing Material

Method	Kind of Sealing Material	From (ft.)	To (ft.)	Sacks Cement
<u>Tra mee</u>	<u>Neat Cement</u>	<u>surface</u>	<u>79</u>	<u>16</u>

13. Were all unused, noncomplying, or unsafe wells properly filled with sealant?
 Yes No If no, explain None

14. Signature of Well Constructor Michael D. Beinborn MB Date Signed 7-15-89
Signature of Drill Rig Operator Michael D. Beinborn MB Date Signed 7-15-89