

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

MAR 19 1974

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

NOTE

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE Town Village City NAME Marietta

2. LOCATION - 1/4 Section NW Section 14 Township TN Range 3 W

OR - Grid or street no. Street name 8

3. OWNER AT TIME OF DRILLING George Reynolds

ADDRESS R3 Boscobel

AND - If available subdivision name, lot & block no. POST OFFICE Wis., 53805

4. Distance in feet from well to nearest:

BUILDING	SANITARY SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE WATER DRAIN
C. I.	TILE	C. I.	SEWER CONNECTED	INDEPENDENT
<u>15'</u>				

CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILLO	ABANDONED WELL	SINK HOLE
C. I.	TILE							

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Country shop

6. DRILLHOLE						9. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	60 <u>83</u>	<u>6</u>	60 <u>83</u>	<u>100</u>	<u>Clay</u>	<u>Surface</u>	<u>40</u>
						<u>sandstone</u>	<u>40</u>	<u>100</u>

7. CASING, LINER, CURBING, AND SCREEN				8. GROUT OR OTHER SEALING MATERIAL			10. TYPE OF DRILLING MACHINE USED		
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Direct Rotary	<input type="checkbox"/> Reverse Rotary
<u>6</u>	<u>new black steel plain end 19.18</u>	<u>Surface</u>	83 <u>83</u>	<u>Clay</u>	<u>Surface</u>	<u>40</u>	<input type="checkbox"/> Rotary - air w/drilling mud	<input checked="" type="checkbox"/> Rotary - hammer with drilling mud & air	<input type="checkbox"/> Jetting with <input type="checkbox"/> Air <input type="checkbox"/> Water
				<u>Cement</u>	<u>40</u>	<u>83</u>	Well construction completed on <u>3 - 1 - 1974</u>		

11. MISCELLANEOUS DATA			Well is terminated		Well disinfected upon completion		Well sealed watertight upon completion	
Yield test:	<u>3 Hrs. at</u>	<u>5 GPM</u>	<u>10</u>	inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below	<u>70</u>	ft. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<u>70</u>	ft. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No

Water sample sent to Madison laboratory on: 3 - 14 - 1974

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphrooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Cospian Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 84 Boscobel, Wis., 53805

Please do not write in space below

COLIFORM TEST RESULT <u>511</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
------------------------------------	---------------	---------------	-----------	---------