

OCT 30 1975

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

NOTE
WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE Town Village City NAME Marietta

2. LOCATION - 1/4 Section SW Section 16 Township 7N Range 3W 3. OWNER AT TIME OF DRILLING Kenneth L. Cooley
OR - Grid or street no. Street name 8 ADDRESS R2

AND - If available subdivision name, lot & block no. POST OFFICE Boscobel, Wis. 53805

4. Distance in feet from well to nearest: (Record answer in appropriate block)

| | | | | |
|------------|----------------|-------------|------------------|-------------------|
| BUILDING | SANITARY SEWER | FLOOR DRAIN | FOUNDATION DRAIN | WASTE WATER DRAIN |
| C. I. | C. I. | C. I. | SEWER CONNECTED | C. I. |
| TILE | TILE | TILE | INDEPENDENT | TILE |
| <u>20'</u> | <u>35'</u> | <u>35'</u> | | |

| | | | | | | | | |
|-------------------|-------------|-------|-------------|------------------|------|-------|----------------|-----------|
| CLEAR WATER DRAIN | SEPTIC TANK | PRIVY | SEEPAGE PIT | ABSORPTION FIELD | BARN | SILLO | ABANDONED WELL | SINK HOLE |
| C. I. | TILE | | | | | | | |
| | <u>60'</u> | | | <u>80'</u> | | | | |

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Trailer home

| 6. DRILLHOLE | | | | | | 9. FORMATIONS | | |
|--------------|----------------|-----------|------------|------------|------------|-------------------------|----------------|------------|
| Dia. (in.) | From (ft.) | To (ft.) | Dia. (in.) | From (ft.) | To (ft.) | Kind | From (ft.) | To (ft.) |
| <u>10</u> | <u>Surface</u> | <u>61</u> | <u>6</u> | <u>61</u> | <u>140</u> | <u>Clay & stone</u> | <u>Surface</u> | <u>20</u> |
| | | | | | | <u>sandstone</u> | <u>20</u> | <u>100</u> |
| | | | | | | <u>hard shale stone</u> | <u>100</u> | <u>140</u> |

| 7. CASING, LINER, CURBING, AND SCREEN | | | |
|---------------------------------------|--|----------------|-----------|
| Dia. (in.) | Kind and Weight | From (ft.) | To (ft.) |
| <u>6</u> | <u>new black steel plain end 18.97</u> | <u>Surface</u> | <u>61</u> |

| 8. GROUT OR OTHER SEALING MATERIAL | | | 10. TYPE OF DRILLING MACHINE USED | | |
|------------------------------------|----------------|-----------|--|---|---|
| Kind | From (ft.) | To (ft.) | <input type="checkbox"/> Cable Tool | <input type="checkbox"/> Direct Rotary | <input type="checkbox"/> Reverse Rotary |
| <u>puddled clay</u> | <u>Surface</u> | <u>20</u> | <input type="checkbox"/> Rotary - air w/drilling mud | <input checked="" type="checkbox"/> Rotary - hammer with drilling mud & air | <input type="checkbox"/> Jetting with <input type="checkbox"/> Air <input type="checkbox"/> Water |
| <u>Cement</u> | <u>20</u> | <u>61</u> | Well construction completed on <u>10-4-1975</u> | | |

| 11. MISCELLANEOUS DATA | | |
|--|--|--|
| Yield test: <u>3</u> Hrs. at <u>5</u> GPM | Well is terminated <u>10</u> inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade | Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No |
| Depth from surface to normal water level <u>80</u> ft. | Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | |
| Depth to water level when pumping <u>92</u> ft. | | |

Water sample sent to Madison laboratory on: 10-27-1975

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coopian Registered Well Driller COMPLETE MAIL ADDRESS Boscobel Wis. 53805
R3 Box 84

Please do not write in space below

| | | | | |
|---------------------------------|---------------|---------------|-----------|---|
| COLIFORM TEST RESULT <u>513</u> | GAS - 24 HRS. | GAS - 48 HRS. | CONFIRMED | REMARKS <input checked="" type="checkbox"/> |
|---------------------------------|---------------|---------------|-----------|---|