

WELL CONSTRUCTOR'S REPORT

Well-6

SEP 24 1970

STATE OF WISCONSIN  
DEPARTMENT OF NATURAL RESOURCES  
Box 450  
Madison, Wisconsin 53701

WHITE COPY - DIVISION'S COPY  
GREEN COPY - DRILLER'S COPY  
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE  Town  Village  City NAME Marietta

2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)  
NW 1/4 Sec. 22 T8N R3W

3. OWNER AT TIME OF DRILLING Daniel Colson

4. OWNER'S COMPLETE MAIL ADDRESS  
R1 Box 42 Roscobel, Wis., 53805

5. Distance in feet from well to nearest: (Record answer in appropriate block)

BUILDING C.I.	SANITARY SEWER C.I.	FLOOR DRAIN C.I.	FOUNDATION DRAIN SEWER CONNECTED	FOUNDATION DRAIN INDEPENDENT	WASTE WATER DRAIN C.I.
15'					

CLEAR WATER DRAIN C.I.	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILLO	ABANDONED WELL	SINK HOLE
		65'						

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

6. Well is intended to supply water for: Country home

7. DRILLHOLE						10. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10"	Surface	70	6	70	100	Clay	Surface	20
						loose stone	20	50
						soft sandstone	50	60
						hard sandstone	60	100

8. CASING, LINER, CURBING, AND SCREEN

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	new black steel plain end 19.18	Surface	70

9. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Clay	Surface	20
Cement	20	70

11. MISCELLANEOUS DATA

Yield test: 4 Hrs. at 12 GPM

Well is terminated 18 inches  above  below final grade

Depth from surface to normal water level 60 ft. Well disinfected upon completion  Yes  No

Depth to water level when pumping 62 ft. Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on: 9-21-1970

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphrooms, access pits, etc., should be given on reverse side.

SIGNATURE Benneth Coplan Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 84 Roscobel, Wis., 53805

Please do not write in space below

COLIFORM TEST RESULT	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
516				