

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

APR 20 1973 21703

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

NOTE

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE Town Village City NAME Marietta

2. LOCATION - 1/4 Section SW Section 29 Township 8N Range 3W 3. OWNER AT TIME OF DRILLING Hartman Steime

OR - Grid or street no. Street name ADDRESS R7D

AND - If available subdivision name, lot & block no. POST OFFICE Boscobel, Wis., 53805

4. Distance in feet from well to nearest: BUILDING 80' SANITARY SEWER C.I. 95' FLOOR DRAIN C.I. 95' FOUNDATION DRAIN SEWER CONNECTED INDEPENDENT WASTE WATER DRAIN C.I. TILE

CLEAR WATER DRAIN C.I. TILE SEPTIC TANK 100' PRIVY SEEPAGE PIT 110' ABSORPTION FIELD BARN SILO ABANDONED WELL SINK HOLE

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Country home

6. DRILLHOLE						9. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
10	Surface	60	6	60	160	Clay & loose stone	Surface	10	
						sand & Clay	10	50	
						limestone	50	75	
						hard shalestone	75	110	
						sandstone	110	160	

7. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	new black steel plain end 19.18	Surface	60

8. GROUT OR OTHER SEALING MATERIAL			10. TYPE OF DRILLING MACHINE USED		
Kind	From (ft.)	To (ft.)	<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Direct Rotary	<input type="checkbox"/> Reverse Rotary
Clay	Surface	10	<input type="checkbox"/> Rotary - air w/drilling mud	<input checked="" type="checkbox"/> Rotary - hammer with drilling mud & air	<input type="checkbox"/> Jetting with <input type="checkbox"/> Air <input type="checkbox"/> Water
Cement	10	60	Well construction completed on 4 - 2 - 19 73		

11. MISCELLANEOUS DATA
Yield test: 2 Hrs. at 8 GPM
Well is terminated 10 inches above below final grade
Well disinfected upon completion Yes No
Well sealed watertight upon completion Yes No

Depth from surface to normal water level 110 ft.
Depth to water level when pumping 118 ft.
Water sample sent to Madison laboratory on: 4 - 16 - 19 73

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Copian Registered Well Driller COMPLETE MAIL ADDRESS Boscobel R3 Box 84 Wis., 53805

Please do not write in space below

COLIFORM TEST RESULT 517 REV. 3-71	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
--	---------------	---------------	-----------	---------