

FEB 27 1978

NOTE:

White Copy - Division's Copy  
Green Copy - Driller's Copy  
Yellow Copy - Owner's Copy

1. COUNTY <b>Crawford</b>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name <b>Marietta</b>	
2. LOCATION OR - Grid or Street No. <b>NW</b> Section <b>29</b> Township <b>7N</b> Range <b>3W</b>		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE <b>Carl Achenbach</b>		ADDRESS <b>R1</b>	
AND - If available subdivision name, lot & block No. <b>(8)</b>		POST OFFICE <b>Boscobel, Wis. 53805</b>			
4. Distance in feet from well to nearest: (Record answer in appropriate block)		Building <b>15</b>		Sanitary Bldg. Drain C.I. Other	
		Sanitary Bldg. Sewer C.I. Other		Floor Drain Connected To: C.I. Sewer Other Sewer	
		Storm Bldg. Drain C.I. Other		Storm Bldg. Sewer C.I. Other	
Street Sewer San. Storm		Other Sewers C.I. Other		Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr.	
				Sewage Sump Clearwater Sump	
				Clearwater Sump <b>65'</b>	
Privy Pet Waste Pit		Pit: Nonconforming Existing Well Pump Tank		Subsurface Pumproom Nonconforming Existing	
				Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit	
Temporary Manure Stack		Watertight Liquid Manure Tank		Solid Manure Storage Structure	
		Subsurface Gasoline or Oil Tank		Waste Pond or Land Disposal Unit (Specify Type)	
		Other (Give Description)			
5. Well is intended to supply water for: <b>Trailer home</b>			9. FORMATIONS		
6. DRILLHOLE			Kind		
Dia. (in.) From (ft.) To (ft.)			From (ft.) To (ft.)		
<b>10</b> Surface <b>0</b> <b>74</b>			<b>6</b> <b>74</b> <b>95</b>		
			<b>loose stone &amp; clay</b> Surface <b>0</b> <b>60</b>		
			<b>hard shale stone</b> <b>60</b> <b>80</b>		
			<b>sandstone</b> <b>80</b> <b>95</b>		
7. CASING, LINER, CURBING AND SCREEN					
Material, Weight, Specification & Method of Assembly					
Dia. (in.)		From (ft.)		To (ft.)	
<b>6</b>		Surface <b>0</b>		<b>74</b>	
<b>new black steel R.E. 18.97</b>					
<b>A-53</b>					
<b>Valley Steel</b>					
8. GROUT OR OTHER SEALING MATERIAL					
Kind		From (ft.)		To (ft.)	
<b>Cement</b>		Surface <b>0</b>		<b>74</b>	
10. TYPE OF DRILLING MACHINE USED					
<input type="checkbox"/> Cable Tool		<input type="checkbox"/> Rotary-hammer w/drilling mud & air		<input type="checkbox"/> Jetting with	
<input type="checkbox"/> Rotary-air w/drilling mud		<input checked="" type="checkbox"/> Rotary-hammer & air		<input type="checkbox"/> Air	
<input type="checkbox"/> Rotary-w/drilling mud		<input type="checkbox"/> Reverse Rotary		<input type="checkbox"/> Water	
Well construction completed on <b>1-28-1978</b>					
11. MISCELLANEOUS DATA					
Yield Test: <b>4</b> Hrs. at <b>5</b> GPM		Well is terminated <b>12</b> inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below			
Depth from surface to normal water level <b>45</b> Ft.		Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Depth of water level when pumping <b>52</b> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Water sample sent to <b>Madison</b> laboratory on <b>2-21-1978</b>					
Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.					
Signature <b>Kenneth Coplan</b> 519			Complete Mail Address <b>Boscobel, Wis. R3 Box 84 53805</b>		
Registered Well Driller					