

NOTE:

White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

Rev. 3-87
 DEC 18 1987

1. COUNTY Crawford		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City			Name Marietta								
2. LOCATION 1/4 Section or Gov't. Lot SE 1/4 NW 16 SW Section 16 Township BN Range R3W OR - Grid or Street No. Street or Road Name AND - If available subdivision name, lot & block No.		3. NAME <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE John Seeley ADDRESS RFD 2 POST OFFICE Boscobel ZIP CODE 53805											
4. Distance in feet from well to nearest: (Record answer in appropriate block) 15' house		Building		Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer	
		C.I. Other		C.I. Other		C.I. Sewer Other Sewer		C.I. Other		C.I. Other		C.I. Other	
Street Sewer		Other Sewers		Foundation Drain Connected to:		Sewage Sump		Clearwater Sump		Septic Tank		Holding Tank	
San. Storm C.I. Other		Sewer Clearwater Dr.		Sewage Sump Clearwater Sump		C.I. Other						Sewage Absorption Unit Seepage Pit Seepage Bed Seepage Trench	
Privy		Pet Waste Pit		Pit: Nonconforming Existing		Subsurface Pumproom		Barn Gutter		Animal Barn Pen		Animal Yard	
				Well Pump Tank		Nonconforming Existing				Silo With Pit		Glass Lined Storage Facility	
Temporary Manure Stack or Platform		Watertight Liquid Manure Tank or Basin		Manure Pressure Pipe		Subsurface Gasoline or Oil Tank		Waste Pond or Land Disposal Unit (Specify Type)		Manure Storage Basin Concrete Floor Only Concrete Floor and Partial Concrete Walls		Other (Describe)	
5. Well is intended to supply water for: Private					9. FORMATIONS								
6. DRILLHOLE					Kind								
Dia. (in.) From (ft.) To (ft.) Dia. (in.) From (ft.) To (ft.)					From (ft.) To (ft.)								
10 Surface 63					loose rocks' dirt Surface 0 13								
6 63 80					loose rock 13 31								
					soft shale 31 60								
					hard shale 60 80								
7. CASING, LINER, CURBING AND SCREEN													
Material, Weight, Specification													
Dia. (in.) Mfg. & Method of Assembly					From (ft.) To (ft.)								
6 New Black steel Plain End					Surface 63'								
CAC ASTM A 53													
6x21 #18.97 780W													
8. GROUT OR OTHER SEALING MATERIAL					10. TYPE OF DRILLING MACHINE USED								
Kind From (ft.) To (ft.)					<input type="checkbox"/> Cable Tool <input type="checkbox"/> Rotary-hammer w/drilling mud & air <input type="checkbox"/> Jetting with <input type="checkbox"/> Rotary-air w/drilling mud <input checked="" type="checkbox"/> Rotary-hammer & air <input type="checkbox"/> Air <input type="checkbox"/> Rotary-w/drilling mud <input type="checkbox"/> Reverse Rotary <input type="checkbox"/> Water								
Pitless Surface 7'					Well construction completed on 11-27 19 87								
Cement 7 63					Well is terminated 10 inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade								
11. MISCELLANEOUS DATA					Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No								
Yield Test: 2 Hrs. at 7 GPM					Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No								
Depth from surface to normal water level 27 Ft.					Water sample sent to Madison laboratory on 12-16 19 87								
Depth of water level when pumping 46 Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No					Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.								
Signature Michael D. Berbon Registered Well Driller					Business Name and Complete Mailing Address Corporan Well Drilling RR 2 Boscobel, WI 53805								