

NOTE:

White Copy - Division's Copy  
 Green Copy - Driller's Copy  
 Yellow Copy - Owner's Copy

JUN 22 1978

1. COUNTY <u>Crawford</u>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name <u>Marietta</u>	
2. LOCATION		1/4 Section <u>NE</u>	Section <u>3</u>	Township <u>8N</u>	Range <u>4W</u>
OR - Grid or Street No.		Street Name		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE <u>Carmen Blacconis</u>	
AND - If available subdivision name, lot & block No.				ADDRESS <u>R7D</u>	
				POST OFFICE <u>Steuben, Wis. 54657</u>	
4. Distance in feet from well to nearest: (Record answer in appropriate block)		Building <u>12'</u>	Sanitary Bldg. Drain C.I. Other	Sanitary Bldg. Sewer C.I. Other	Floor Drain Connected To: C.I. Sewer Other Sewer
Street Sewer San. Storm		Other Sewers C.I. Other	Foundation Drain Connected to: Sewer Clearwater Dr.	Sewage Sump C.I. Other	Clearwater Sump
				Septic Tank <u>50'</u>	Holding Tank
				Sewage Absorption Unit <u>70'</u> Seepage Pit Seepage Bed Seepage Trench	
Privy	Pet Waste Pit	Pit: Nonconforming Existing Well Pump Tank	Subsurface Pumproom Nonconforming Existing	Barn Gutter	Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit
Temporary Manure Stack	Watertight Liquid Manure Tank	Solid Manure Storage Structure	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Other (Give Description)
5. Well is intended to supply water for: <u>Trailer home</u>			9. FORMATIONS		
6. DRILLHOLE			Kind		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>40</u>	<u>6</u>	<u>40</u>	<u>100</u>
			Clay		
			hard shalestone		
			hard sandstone		
			Surface <u>0</u> <u>15</u>		
			<u>15</u> <u>65</u>		
			<u>65</u> <u>100</u>		
7. CASING, LINER, CURBING AND SCREEN					
Material, Weight, Specification & Method of Assembly					
Dia. (in.)	From (ft.)		To (ft.)		
<u>6</u>	<u>Surface</u>		<u>40</u>		
<u>new black steel</u>					
<u>P.E. 18.97</u>					
<u>A-53</u>					
<u>Valley Steel</u>					
<u>Pitless adaptor</u>					
8. GROUT OR OTHER SEALING MATERIAL					
Kind		From (ft.)	To (ft.)		
<u>Clay</u>		<u>Surface</u>	<u>7</u>		
<u>Cement</u>		<u>7</u>	<u>40</u>		
10. TYPE OF DRILLING MACHINE USED					
<input type="checkbox"/> Cable Tool		<input type="checkbox"/> Rotary-hammer w/drilling mud & air		<input type="checkbox"/> Jetting with	
<input type="checkbox"/> Rotary-air w/drilling mud		<input checked="" type="checkbox"/> Rotary-hammer & air		<input type="checkbox"/> Air	
<input type="checkbox"/> Rotary-w/drilling mud		<input type="checkbox"/> Reverse Rotary		<input type="checkbox"/> Water	
Well construction completed on <u>5-19-1978</u>					
11. MISCELLANEOUS DATA					
Yield Test: <u>4</u> Hrs. at <u>5</u> GPM		Well is terminated <u>10</u> inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below			
Depth from surface to normal water level <u>60</u> Ft.		Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Depth of water level when pumping <u>68</u> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Water sample sent to <u>Madison</u> laboratory on <u>6-5-1978</u>					
Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.					
Signature <u>Kenneth Coplan</u> 528			Complete Mail Address <u>Booscobal, Wis.</u> <u>R3 Box 84</u> <u>53805</u>		