

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Marietta

2. LOCATION SE of NE Section 19 Township 8N Range 4W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Everett O'Brian

OR - Grid or Street No. Street or Road Name ADDRESS 3W

AND - If available subdivision name, lot & block No. POST OFFICE Boscobel Wi ZIP CODE 53805

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 15' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewer Clearwater Dr. Sewage Sump C.I. Other Sewage Sump Clearwater Sump Clearwater Sump Clearwater Sump Sewage Absorption Unit Seepage Pit Seepage Bed Seepage Trench 70' Manure Hopper or Retention or Pneumatic Tank

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit Earthen Manure Basin

Temporary Manure Stack or Platform Watertight Liquid Manure Tank or Basin Manure Pressure Pipe Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Manure Storage Basin Concrete Floor Only Concrete Floor and Partial Concrete Walls Other (Describe)

5. Well is intended to supply water for: Country Home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	Surface	147	6	147	420

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	From (ft.)	To (ft.)
6	new black steel PE 18.97	Surface	147
	A-53 Valley steel Pitless adaptor		

9. FORMATIONS

Kind	From (ft.)	To (ft.)
clay	Surface	6
shale rock	6	35
lime rock	35	260
sand rock	260	420

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
clay	Surface	8
cement	8	147

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with Air Water

Rotary-air w/drilling mud Rotary-hammer & air

Rotary-w/drilling mud Reverse Rotary

Well construction completed on 5-21 1982

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 8 GPM Well is terminated 12 inches above final grade below

Depth from surface to normal water level 360 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 365 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 6-7 1982

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Donald C. Kirschbaum Registered Well Driller Business Name and Complete Mailing Address RT4 Box 75 Boscobel WI 53805