

OCT 12 1972

11059

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

NOTE
WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE Town Village City NAME Eastman

2. LOCATION - 1/4 Section SW Section 8 Township 8N Range 4W 3. OWNER AT TIME OF DRILLING Mr. Dale Bruegmann
OR - Grid or street no. Street name ADDRESS R7D

AND - If available subdivision name, lot & block no. POST OFFICE Steuben, Wis., 54657

4. Distance in feet from well to nearest:
(Record answer in appropriate block)

BUILDING C. I.	SANITARY SEWER TILE	FLOOR DRAIN C. I.	FOUNDATION DRAIN SEWER CONNECTED	WASTE WATER DRAIN C. I.
<u>60'</u>	<u>70'</u>	<u>125'</u>		<u>70'</u>
CLEAR WATER DRAIN C. I.	SEPTIC TANK TILE	PRIVY	SEEPAGE PIT	ABSORPTION FIELD
	<u>80'</u>			<u>85'</u>

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Country home

6. DRILLHOLE						9. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
<u>6</u>	<u>Surface</u>	<u>155</u>				<u>loose sand</u>	<u>Surface</u>	<u>130</u>
						<u>sandstone</u>	<u>130</u>	<u>145</u>
						<u>hard shalestone</u>	<u>145</u>	<u>155</u>

7. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel plain end 19.18</u>	<u>Surface</u>	<u>139</u>

8. GROUT OR OTHER SEALING MATERIAL

Kind <u>loose sand</u>	From (ft.) <u>Surface</u>	To (ft.)
------------------------	---------------------------	----------

10. TYPE OF DRILLING MACHINE USED

Cable Tool Direct Rotary Reverse Rotary
 Rotary - air w/drilling mud Rotary - hammer with drilling mud & air Jetting with Air Water

Well construction completed on 9-27- 1972

11. MISCELLANEOUS DATA

Yield test: 2 Hrs. at 12 GPM

Well is terminated 10 inches above below final grade

Depth from surface to normal water level 110 ft. Well disinfected upon completion Yes No

Depth to water level when pumping 110 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 10-9- 1972

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Copian Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 84 Rosobel, Wis., 53805

Please do not write in space below

COLIFORM TEST RESULT <u>530</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
------------------------------------	---------------	---------------	-----------	---------