

1. COUNTY Crawford CHECK ONE  Town  Village  City NAME Steuben

2. LOCATION (Number and Street or ¼ section, section, township and range. Also give subdivision name, lot and block numbers when available.)  
Block 4 Farris addition Lot 6 T. 8N, R. 4W, Sec. 9

3. OWNER AT TIME OF DRILLING L. Earl Daugherty

4. OWNER'S COMPLETE MAIL ADDRESS Steuben, Wis.

5. Distance in feet from well to nearest:

(Record answer in appropriate block)	BUILDING		SANITARY SEWER		FLOOR DRAIN		FOUNDATION DRAIN		WASTE WATER DRAIN	
	C. I.	TILE	C. I.	TILE	C. I.	TILE	SEWER CONNECTED	INDEPENDENT	C. I.	TILE
		8'		25'						25'

CLEAR WATER DRAIN		SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILLO	ABANDONED WELL	SINK HOLE
C. I.	TILE								
		60'	-	65'					

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)  
none

6. Well is intended to supply water for: Home

7. DRILLHOLE						10. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
10	Surface	49	6	49	75	Clay & stone	Surface	15	
						shalestone	15	40	
						sandstone	40	75	

8. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	plain <del>black</del> end black 19.18	Surface	49

9. GROUT OR OTHER SEALING MATERIAL		
Kind	From (ft.)	To (ft.)
Clay	Surface	15
Cement	15	49

Well construction completed on Sept. 6 1967

11. MISCELLANEOUS DATA			
Yield test:	2 Hrs. at	50 GPM	Well is terminated <u>18</u> inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade
Depth from surface to normal water level	2.5	ft.	Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Depth to water level when pumping	2.5	ft.	Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Water sample sent to <u>Madison</u>	laboratory on: <u>9-13</u> - 19 <u>67</u>		

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE	COMPLETE MAIL ADDRESS
<u>Benjamin Coplan</u> Registered Well Driller	<u>R3 Box 84 Boscobel, Wis. 53805</u>

Please do not write in space below

COLIFORM TEST RESULT	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
539				