

AUG 14 1978

NOTE:
White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Eastman

2. LOCATION 1/4 Section Section Township Range 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE
 OR - Grid or Street No. Street Name Sec 9 4 ADDRESS Ole McCullick
Stauben
 AND - If available subdivision name, lot & block No. POST OFFICE WV. 54657
village of Stauben 9 E 10

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 10' Sanitary Bldg. Drain Sanitary Bldg. Sewer Floor Drain Connected To: Storm Bldg. Drain Storm Bldg. Sewer

San.	Storm	C.I.	Other	Sewer	Sewage Sump	C.I.	Other	Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit <u>78'</u>	
				Clearwater Dr.	Clearwater Sump						Seepage Pit	
											Seepage Bed	
											Seepage Trench	

5. Well is intended to supply water for: Home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
<u>10</u>	<u>Surface</u>	<u>68</u>	<u>6</u>	<u>68</u>	<u>90</u>	<u>Clay's stone</u>	<u>Surface</u>	<u>0</u>	<u>30</u>
						<u>shalestone</u>		<u>30</u>	<u>45</u>
						<u>sandstone</u>		<u>45</u>	<u>90</u>

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel P.E. 18.97 A-53</u>	<u>Surface</u>	<u>68</u>
	<u>Kent steel</u>		
	<u>Pitless adaptor</u>		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>8</u>
<u>Cement</u>	<u>8</u>	<u>68</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with Air Water

Rotary-air w/drilling mud Rotary-hammer & air

Rotary-w/drilling mud Reverse Rotary

Well construction completed on 8-1- 19 78

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 5 GPM Well is terminated 10 inches above final grade below

Depth from surface to normal water level 54 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 72 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 8-8- 19 78

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Copson Registered Well Driller Complete Mail Address R3 Box 84 Boscobel, WV, 53805

540