

WELL CONSTRUCTOR'S REPORT

Well-6

JUL 30 1970

SEP 15 1970

STATE OF WISCONSIN  
DEPARTMENT OF NATURAL RESOURCES  
Box 450  
Madison, Wisconsin 53701

WHITE COPY - DIVISION'S COPY  
GREEN COPY - DRILLER'S COPY  
YELLOW COPY - OWNER'S COPY

AUG 17 1970

1. COUNTY Grant CRAWFORD CHECK ONE  Town  Village  City NAME Steuben

2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)  
Petersons addition Lot 1 SE 1/4 of Sec. 9 T8N R4W

3. OWNER AT TIME OF DRILLING Melvin Smith

4. OWNER'S COMPLETE MAIL ADDRESS Steuben, Wis. 54657

5. Distance in feet from well to nearest: (Record answer in appropriate block)

BUILDING	SANITARY SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE WATER DRAIN
C. I.	TILE	C. I.	SEWER CONNECTED	INDEPENDENT

CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILLO	ABANDONED WELL	SINK HOLE
C. I.	TILE							

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

6. Well is intended to supply water for: Home

7. DRILLHOLE						10. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
<del>6</del>	Surface	<del>100</del>						
10	0	15	6	15	100	Clay	Surface	15
						loose sand	15	65
						sandstone	65	100

8. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	new black steel plain end 19.18	Surface	80

9. GROUT OR OTHER SEALING MATERIAL		
Kind	From (ft.)	To (ft.)
Clay	Surface	15
loose sand	15	65

11. MISCELLANEOUS DATA

Yield test: 2 Hrs. at 8 GPM

Well is terminated 18 inches  above  below final grade

Depth from surface to normal water level 55 ft. Well disinfected upon completion  Yes  No

Depth to water level when pumping 60 ft. Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on: 8-11-1970

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphrooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Cospian Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 84 Boscobel Wis. 53805

Please do not write in space below

COLIFORM TEST RESULT	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
542				