

AUG 2 1982

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Castman Name

2. LOCATION SE Section 5 Township 8N Range 4W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE  
 ADDRESS 1634 N. Major Ave  
 POST OFFICE Chicago, Ill. ZIP CODE 60639

4. Distance in feet from well to nearest: (Record answer in appropriate block)

Building	Sanitary Bldg. Drain	Sanitary Bldg. Sewer	Floor Drain Connected To:	Storm Bldg. Drain	Storm Bldg. Sewer
<u>2</u>	<u>C.I.</u>	<u>Other</u>	<u>N/A</u>	<u>C.I.</u>	<u>Other</u>

Street Sewer	Other Sewers	Foundation Drain Connected to:	Sewage Sump	Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit	Manure Hopper or Retention or Pneumatic Tank
San. Storm	C.I. Other	Sewer	Sewage Sump	Clearwater Dr.	C.I. Other		Seepage Pit Seepage Bed Seepage Trench	
			<u>N/A</u>					

Privy	Pet Waste Pit	Pit: Nonconforming Existing	Subsurface Pumproom	Barn Gutter	Animal Barn Pen	Animal Yard	Silo With Pit	Glass Lined Storage Facility	Silo w/o Pit	Earthen Silage Storage Trench Or Pit	Earthen Manure Basin
		Well Pump Tank	Nonconforming Existing								
		<u>←</u>	<u>N/A</u>								

Temporary Manure Stack or Platform	Watertight Liquid Manure Tank or Basin	Manure Pressure Pipe	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Manure Storage Basin	Other (Describe)
					Concrete Floor Only Concrete Floor and Partial Concrete Walls	

5. Well is intended to supply water for: mobile home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	9. FORMATIONS	Kind	From (ft.)	To (ft.)
10	Surface	63	6	63	100	loose limestone	Surface	0	39
						soft shalestone		39	53
						hard shalestone		53	100

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	From (ft.)	To (ft.)
6	A 53 18.97 <sup>10</sup> / <sub>5</sub> ft Swington Pipe Tube P.E. Pitless adapter	Surface	63

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
clay	Surface	8
cement	8	63

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Rotary-hammer w/drilling mud & air  Jetting with

Rotary-air w/drilling mud  Rotary-hammer & air  Air

Rotary-w/drilling mud  Reverse Rotary  Water

Well construction completed on 6-12 1981

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 10 GPM Well is terminated 15 inches  above final grade  below

Depth from surface to normal water level 60 Ft. Well disinfected upon completion  Yes  No

Depth of water level when pumping 67 Ft. Stabilized  Yes  No Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on 7-27 1982

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Phil Caplan Registered Well Driller

Business Name and Complete Mailing Address: Kenneth Corporation & Sons, Inc  
Pt. 2 Box 4 Boscobel, WI 53805

55