

1. COUNTY Crawford CHECK ONE  Town  Village  City NAME Steuben APR 25 1966

2. LOCATION (Number and street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)

3. OWNER AT TIME OF DRILLING Mrs. Elsie Daugherty **SANITARY ENGINEERING**

4. OWNER'S COMPLETE MAIL ADDRESS Steuben, Wisconsin Section 16 T8NR4W

Location → Lot - 8 - 9 - 10 - 13 1/2 off E. side Lot 7

5. Distance in feet from well to nearest:

BUILDING	SANITARY SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE WATER DRAIN
10'	C. I.	TILE	C. I.	TILE
		60'	SEWER CONNECTED	INDEPENDENT

CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
C. I.	TILE							
60'	60'	0	75	0	0	0	0	0

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)  
0

6. Well is intended to supply water for: Steuben store

7. DRILLHOLE						10. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
6	Surface	95				sand & Clay	Surface	25
						loose sand	25	50

8. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6"	Standard wt. #19 1/8	Surface	64

*Casing was driven thru loose formation into hard shale stone*

9. GROUT OR OTHER SEALING MATERIAL		
Kind	From (ft.)	To (ft.)
Clay	Surface	25

11. MISCELLANEOUS DATA	
Yield test: <u>3</u> Hrs. at <u>20</u> GPM	Well is terminated <u>10</u> inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade
Depth from surface to normal water level <u>20</u> ft.	Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Depth to water level when pumping <u>25</u> ft.	Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No

Well construction completed on 8-3-1965

Water sample sent to Madison, Wis. laboratory on: Apr. 19 1966

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphrooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coplan Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 36 Boscobel, Wis. 53805

Please do not write in space below

COLIFORM TEST RESULT	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
552				