

JUN 13 1977

NOTE:

White Copy - Division's Copy  
 Green Copy - Driller's Copy  
 Yellow Copy - Owner's Copy

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Name Eastman

2. LOCATION NE Section 18 Township 8N Range 4W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE William Benoy

OR - Grid or Street No. Street Name ADDRESS RFD

AND - If available subdivision name, lot & block No. POST OFFICE Wauzeka, Wis., 53826

4. Distance in feet from well to nearest: (Record answer in appropriate block) 60'

Building		Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer	
C.I.	Other	C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other

Street Sewer: San. Storm Other Sewers: C.I. Other Foundation Drain Connected to: Sewage Sump Clearwater Dr. Sewage Sump Clearwater Sump Clearwater Sump

Clearwater Sump: 100' Septic Tank: 100' Holding Tank: 120' Sewage Absorption Unit: Seepage Pit Seepage Bed Seepage Trench

Privy: Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter 250' Animal Barn Pen Animal Yard 250' Silo With Pit 250' Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Country home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>266</u>	<u>6</u>	<u>266</u>	<u>510</u>

9. FORMATIONS

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>10</u>
<u>limestone</u>	<u>10</u>	<u>180</u>
<u>soft sandstone</u>	<u>180</u>	<u>240</u>
<u>limestone</u>	<u>240</u>	<u>480</u>
<u>sandstone</u>	<u>480</u>	<u>510</u>

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel P.E. 18.97 A-53</u>	<u>Surface</u>	<u>266</u>
	<u>Valley Steel</u>		
	<u>Pitless adaptor</u>		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>7</u>
<u>Cement</u>	<u>7</u>	<u>266</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Rotary-hammer w/drilling mud & air  Jetting with  Air  Water

Rotary-air w/drilling mud  Rotary-hammer & air

Rotary-w/drilling mud  Reverse Rotary

Well construction completed on 6-2-1977

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 5 GPM

Depth from surface to normal water level 4.05 Ft.

Depth of water level when pumping 4.15 Ft. Stabilized  Yes  No

Well is terminated 12 inches  above  below final grade

Well disinfected upon completion  Yes  No

Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on 6-6-1977

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature 557 Kenneth Copian Registered Well Driller

Complete Mail Address Boacoba, Wis. R3 Box 84 53805