

1. COUNTY Crawford CHECK ONE Town Village City NAME Marietta

2. LOCATION (Number and Subst or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)
SE 1/4 of NE 1/4 of Sec. 20 T8N R4W

3. OWNER AT TIME OF DRILLING Clifford Larson

4. OWNER'S COMPLETE MAIL ADDRESS R 701 00 Housaka, Wis. 53826

5. Distance in feet from well to nearest: (Record answer in appropriate block)

BUILDING C. I.	SANITARY SEWER C. I.	FLOOR DRAIN TILE	FOUNDATION DRAIN SEWER CONNECTED	FOUNDATION DRAIN INDEPENDENT	WASTE WATER DRAIN C. I.	WASTE WATER DRAIN TILE
30'	40'				40'	

CLEAR WATER DRAIN C. I.	CLEAR WATER DRAIN TILE	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
		80'		90'		125	125	35'	

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

6. Well is intended to supply water for: Farm Home

7. DRILLHOLE						10. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
10	Surface	69	6	69	380	Clay	Surface	20	
						limestone	20	250	
						sandstone	250	380	

8. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	new black steel plain end 19.18	Surface	69

9. GROUT OR OTHER SEALING MATERIAL		
Kind	From (ft.)	To (ft.)
Clay	Surface	20
Cement	20	69

11. MISCELLANEOUS DATA

Yield test: 8 Hrs. at 12 GPM

Well construction completed on 10-3-1968

Well is terminated 12 inches above below final grade

Depth from surface to normal water level 300 ft. Well disinfected upon completion Yes No

Depth to water level when pumping 305 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison, Wis. laboratory on: 10-7-1968

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Benneth Copian Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 84 Roschele, Wis. 53805

Please do not write in space below

COLIFORM TEST RESULT	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
560				