

1. COUNTY Crawford CHECK ONE Town Village City NAME Marietta

2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)
S. W. Part of Sec. 22 T8N R4-EW

3. OWNER AT TIME OF DRILLING Mr. Jesse Lindley

4. OWNER'S COMPLETE MAIL ADDRESS R1 Hauska, Wis., 53826

5. Distance in feet from well to nearest:

BUILDING C. I.	SANITARY SEWER TILE	FLOOR DRAIN C. I.	FOUNDATION DRAIN SEWER CONNECTED	FOUNDATION DRAIN INDEPENDENT	WASTE WATER DRAIN C. I.	WASTE WATER DRAIN TILE
<u>40'</u>						

CLEAR WATER DRAIN C. I.	SEPTIC TANK TILE	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILLO	ABANDONED WELL	SINK HOLE
		<u>80'</u>			<u>120'</u>			

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

6. Well is intended to supply water for: Farm home

7. DRILLHOLE						10. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
<u>10</u>	<u>Surface</u>	<u>116</u>	<u>6</u>	<u>116</u>	<u>240</u>	<u>Clay</u>	<u>Surface</u>	<u>60</u>	
						<u>broken limestone</u>	<u>60</u>	<u>90</u>	
						<u>hard limestone</u>	<u>90</u>	<u>200</u>	
						<u>sandstone</u>	<u>200</u>	<u>240</u>	

8. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<u>6</u>	<u>new black plain ends 19/18</u>	<u>Surface</u>	<u>116</u>

9. GROUT OR OTHER SEALING MATERIAL			
Kind	From (ft.)	To (ft.)	
<u>Clay</u>	<u>Surface</u>	<u>60</u>	
<u>Cement</u>	<u>60</u>	<u>116</u>	

11. MISCELLANEOUS DATA

Yield test: 5 Hrs. at 12 GPM

Well is terminated 14 inches above below final grade

Depth from surface to normal water level 180 ft. Well disinfected upon completion Yes No

Depth to water level when pumping 190 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison, Wis., laboratory on: 5-6- 1968

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphouses, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Copman Registered Well Driller COMPLETE MAIL ADDRESS 53805
R. 3 Box 84 Boscobel, Wis.,

Please do not write in space below

COLIFORM TEST RESULT	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
<u>563</u>				