

JUL 1 1980

1. COUNTY Crawford CHECK (✓) ONE: Stauben Name Marietta
 Town Village City

2. LOCATION SW 9 8N 4W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE
Louise Green
 OR - Grid or Street No. Street Name ADDRESS Stauben,

AND - If available subdivision name, lot & block No. POST OFFICE Wisc. 54657

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 10' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer Other Sewers Foundation Drain Connected to: Sewage Sump Clearwater Sump Septic Tank Holding Tank Sewage Absorption Unit 65'
 San. Storm C.I. Other Sewer Sewage Sump Clearwater Dr. Clearwater Sump C.I. Other

Privy Pet Waste Pit Pit: Nonconforming Existing Subsurface Pumproom Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Trailer home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	Surface	84	6	84	100

9. FORMATIONS

Kind	From (ft.)	To (ft.)
Clay	Surface	10
soft sandstone	10	60
hard shalestone	60	100

7. CASING, LINER, CURBING AND SCREEN
Material, Weight, Specification & Method of Assembly

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	84

new black steel
P.E. 18.97
A-53
Kent Steel
Pitless adapter

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Clay	Surface	7
Cement	7	84

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with Air Water

Rotary-air w/drilling mud Rotary-hammer & air

Rotary-w/drilling mud Reverse Rotary

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 5 GPM

Depth from surface to normal water level 60 Ft.

Depth of water level when pumping 72 Ft. Stabilized Yes No

Well construction completed on 6-18- 1980

Well is terminated 10 inches above below final grade

Well disinfected upon completion Yes No

Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 6-23 198

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Coplan Registered Well Driller Complete Mail Address Boscobel, Wisc.
R2 Box 4 53805