

AUG 4 1976

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Marietta

2. LOCATION NE Section 3 Township 8N Range 5W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE John Richter

OR - Grid or Street No. Street Name ADDRESS RFD

AND - If available subdivision name, lot & block No. POST OFFICE Steuben Wi 54657

4. Distance in feet from well to nearest: (Record answer in appropriate block)

Building	Sanitary Bldg. Drain	Sanitary Bldg. Sewer	Floor Drain Connected To:	Storm Bldg. Drain	Storm Bldg. Sewer
<u>8'</u>	C.I. <u>20'</u> Other	C.I. Other	C.I. Sewer Other Sewer	C.I. Other	C.I. Other

Street Sewer	Other Sewers	Foundation Drain Connected to:	Sewage Sump	Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit
San. Storm	C.I. Other	Sewer Sewage Sump Clearwater Dr.	C.I. Other		<u>50'</u>		<u>75'</u>

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumphouse Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Country home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>65</u>	<u>6</u>	<u>65</u>	<u>80</u>

9. FORMATIONS

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>12</u>
<u>hard shalestone</u>	<u>12</u>	<u>80</u>

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel P.E. 18.97 A-53</u>	<u>Surface</u>	<u>65</u>

Valley Steel
Pitless adaptor

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Cement</u>	<u>Surface</u>	<u>65</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with

Rotary-air w/drilling mud Rotary-hammer & air Air

Rotary-w/drilling mud Reverse Rotary Water

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 6 GPM

Well construction completed on 7-14-1976

Well is terminated 12 inches above final grade below

Depth from surface to normal water level 60 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 63 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 7-29-1976

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature 575 Complete Mail Address Boacobel
Kenneth Coyman Registered Well Driller R3 Box 84 WI 53805