

WELL CONSTRUCTOR'S REPORT TO WISCONSIN STATE BOARD OF HEALTH

Well 6

See Instructions on Reverse Side

RECEIVED

1. County Crawford Town  Eastman Village  City  MAR - 3 1965  
Check one and give name
2. Location Section 5 Range 5 Town 8  
Name of street and number of premise or Section, Town and Range numbers
3. Owner  or Agent  John Zabeck  
Name of individual, partnership or firm
4. Mail Address R 7 D 1 Steuben, Wis.  
Complete address required
5. From well to nearest: Building 25 ft; sewer 250 ft; drain 250 ft; septic tank 300 ft;  
 dry well or filter bed 0 ft; abandoned well 0 ft.

Sanitary Engineering

6. Well is intended to supply water for: Farm home

7. DRILLHOLE:

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	0	41	6	41	375

8. CASING AND LINER PIPE OR CURBING:

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6"	Standard wt.	0	41

9. GROUT:

Kind	From (ft.)	To (ft.)
Clay	0	10
Cement	10	41

11. MISCELLANEOUS DATA:

Yield test: 5 Hrs. at 20 GPM.

Depth from surface to water-level: 300 ft.

Water-level when pumping: 310 ft.

Water sample was sent to the state laboratory at:

Madison on 2-24 1965  
City

10. FORMATIONS:

Kind	From (ft.)	To (ft.)
Black dirt	0	10
Blue limestone	10	105
Galena limestone	105	200
Sandstone	200	275
Hard shalestone	275	310
Sandstone	310	375

Construction of the well was completed on:

Jan. 19 1965

The well is terminated 18 inches  
 above, below  the permanent ground surface.

Was the well disinfected upon completion?

Yes  No

Was the well sealed watertight upon completion?

Yes  No

Signature Kenneth Coplan  
 Registered Well Driller

R 3 Box 36 Boscobel, Wis.  
 Complete Mail Address 53805

Please do not write in space below

Rec'd FEB 25 1965 No. 7393

Ans'd 9961 I MAR 1 1965

Interpretation

SAFE BACTERIOLOGICALLY

10 ml 10 ml 10 ml 10 ml 10 ml

Gas—24 hrs. \_\_\_\_\_

48 hrs. \_\_\_\_\_

Confirm \_\_\_\_\_

B. Coli 00000

Examiner \_\_\_\_\_