

OCT 3 1978

State of Wisconsin  
Department of Natural Resources  
Box 7921  
Madison, Wisconsin 53707

NOTE:

White Copy - Division's Copy  
Green Copy - Driller's Copy  
Yellow Copy - Owner's Copy

WELL CONSTRUCTOR'S REPORT  
Form 3300-15 Rev. 12-76

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Name Marietta

2. LOCATION 1/4 Section NW Section 5 Township 8N Range 5W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE Roger McCullick  
OR - Grid or Street No. Street Name ADDRESS RFD

AND - If available subdivision name, lot & block No. POST OFFICE Steuben, Wis, 54657

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 8' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewer Clearwater Dr. Sewage Sump C.I. Other Clearwater Sump Clearwater Sump Sewage Absorption Unit 110' Seepage Pit Seepage Bed Seepage Trench 75

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumphouse Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Country home

6. DRILLHOLE  
Dia. (in.) From (ft.) To (ft.) Dia. (in.) From (ft.) To (ft.)  
10 Surface 60 6 60 85

9. FORMATIONS  
Kind From (ft.) To (ft.)  
Clay & stone Surface 60  
loose sand 60 70  
gravel bed water bearing 70 85

7. CASING, LINER, CURBING AND SCREEN  
Material, Weight, Specification & Method of Assembly From (ft.) To (ft.)  
6 new black steel P.E. 18.97 Surface 80  
A-53  
Valley steel  
Pitless adaptor

10. TYPE OF DRILLING MACHINE USED  
 Cable Tool  Rotary-air w/drilling mud  Rotary-w/drilling mud  Rotary-hammer w/drilling mud & air  Rotary-hammer & air  Jetting with Air Water  Reverse Rotary

8. GROUT OR OTHER SEALING MATERIAL  
Kind From (ft.) To (ft.)  
Clay Surface 8  
Cement 8 60

Well construction completed on 9-6- 19 78

11. MISCELLANEOUS DATA  
Yield Test: 2 Hrs. at 5 GPM  
Depth from surface to normal water level 50 Ft.  
Depth of water level when pumping 62 Ft. Stabilized  Yes  No

Well is terminated 10 inches  above  below final grade  
Well disinfected upon completion  Yes  No  
Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on 9-27- 19 78

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Coplan Registered Well Driller

Complete Mail Address Boscobel, Wis,  
R3 Box 84  
53805