


**First Water Quality Test For
WISCONSIN UNIQUE WELL NUMBER AS 864**

AUG 4 1988 State of Wisconsin
Department of Natural Resources
Private Water Supply - WS/2
Box 7921
Madison, WI 53707

Property Owner: Joe Torok Telephone Number: _____
Mailing Address: 6548 N. Talman
City: Chicago, Ill State: _____ Zip Code: 60648
County: Crawford County Well Location: _____ Well Completion Date: 4/20/88
Permit No.: W

1. Location (Please type or print using a black pen.)
 Town City Village Fire # (if available)
of EASTMAN
Grid or Street Address or Road Name and Number (if available): _____
Subdivision Name: _____ Lot #: _____ Block #: _____

Well Constructor (Business Name) - Registration #
Donnell Drilling 170
Address: 16189 Dutch Hill Rd
City: Boscobel State: WI Zip Code: 53805



Gov't Lot # _____ or SE 1/4 of NE 1/4 of Section 9 T 8 N; R 4 E W

3. Well Type New
 Replacement Reconstruction/Rehabilitation
of well constructed in 19 _____
Reason for new, reconstructed, replaced, or rehabilitated well?
 Drilled Driven Point Jetted Other _____

4. Well serves 1 of homes and/or _____
(ex: barn, restaurant, church, school, industry, etc.)
High Capacity Well? Yes No
High Capacity Property? Yes No

5. Well Located on Highest Point of Property, Consistent with the General Layout and Surroundings? Yes No
Well Located in Floodplain? Yes No
Distance In Feet From Well To Nearest:
1. Landfill _____
35' 2. Building Overhang _____
Not In 3. Septic or Holding Tank _____
4. Sewage Absorption Unit _____
5. Nonconforming Pit _____
6. Buried Home Heating Oil Tank _____
7. Buried Petroleum Tank _____
8. Shoreline/Swimming Pool _____
9. Downspout/Yard Hydrant _____
10. Privy _____
11. Foundation Drain to Clearwater _____
12. Foundation Drain to Sewer _____
13. Building Drain _____
 Cast Iron or Plastic Other _____
14. Building Sewer Gravity Pressure _____
 Cast Iron or Plastic Other _____
15. Collector Sewer _____
16. Clearwater Sump _____
17. Wastewater Sump _____
18. Paved Animal Barn Pen _____
19. Animal Yard or Shelter _____
20. Silo - Type _____
21. Barn Gutter _____
22. Manure Pipe Gravity Pressure _____
 Cast Iron or Plastic Other _____
23. Other Manure Storage _____
Other NR 112 Waste Source _____
24. _____

6. Drillhole Dimensions
From To
Dia. (in.) (ft.) (ft.)
10 surface 98
Method of constructing upper enlarged drillhole. (If applicable - more than one.)
 1. Rotary - Mud Circulation
 2. Rotary - Air
 3. Rotary - Foam
 4. Reverse Rotary
 5. Cable-tool Bit _____ in. dia.
 6. Temp. Outer Casing _____ in. dia.
Removed? Yes No
If no, explain _____
 7. Other _____

9. Geology

Type, Caving/Noncaving, Color, Hardness, Etc.	From (ft.)	To (ft.)
<u>sand</u>	surface	<u>10</u>
<u>loose sandrock</u>	<u>10</u>	<u>88</u>
<u>sand rock</u>	<u>88</u>	<u>120</u>

7. Casing, Liner, Screen
Material, Weight, Specification From To
Dia. (in.) Mfg. & Method of Assembly (ft.) (ft.)
6 new black steel surface 98
PE 18.97
PS1-1200
A-120
L PS-1200
screen type and material adapter From To

10. Static Water Level _____ ft. above ground level
80 ft. below ground surface
11. Pump Test
Pumping Level 83 ft. below surface
Pumping at 8 GPM for 3 hours
12. Well Is:
 Above Grade
 Below Grade
12 in.
Developed? Yes No
Disinfected? Yes No
Capped? Yes No

8. Grout or Other Sealing Material
Method From To Sacks
Kind of Sealing Material (ft.) (ft.) Cement
clay surface 8 8
cement 8 98 33

13. Were all unused, noncomplying, or unsafe wells properly filled with sealant?
 Yes No If no, explain _____
14. Signature of Well Constructor: Donnell A. Kirschbaum Date Signed: 8-2-88
Signature of Drill Rig Operator: Don Kirschbaum Date Signed: 8-2-88