

NOTE:

White Copy - Division's Copy  
 Green Copy - Driller's Copy  
 Yellow Copy - Owner's Copy

1. COUNTY <u>Crawford</u>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name <u>Marietta</u>			
2. LOCATION ¼ Section or Gov't. Lot <u>NE¼, NE¼</u> OR - Grid or Street No.    Street or Road Name		Section <u>9</u>	Township <u>8N</u>	Range <u>4W</u>	3. NAME <input type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE <u>David Cade</u> ADDRESS <u>1705 Washington St.</u> POST OFFICE <u>Mt. Horeb, Wi.</u> ZIP CODE <u>53572</u>		
4. Distance in feet from well to nearest: (Record answer in appropriate block) <u>50'</u>		Building	Sanitary Bldg. Drain	Sanitary Bldg. Sewer	Floor Drain Connected To:	Storm Bldg. Drain	Storm Bldg. Sewer
		C.I.	Other	C.I.	Other	C.I.	Other
Street Sewer	Other Sewers	Foundation Drain Connected to:		Sewage Sump	Clearwater Sump	Septic Tank	Holding Tank
San.	Storm	C.I.	Other	Sewer	Sewage Sump		
				Clearwater Dr.	Clearwater Sump		
Privy	Pet Waste Pit	Pit: Nonconforming Existing		Subsurface Pumproom	Barn Gutter	Animal Barn Pen	Animal Yard
		Well		Nonconforming Existing			Silo With Pit
		Pump					Glass Lined Storage Facility
		Tank					Silo w/o Pit
							Earthen Silage Storage Trench Or Pit
							Earthen Manure Basin
Temporary Manure Stack or Platform	Watertight Liquid Manure Tank or Basin	Manure Pressure Pipe	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Manure Storage Basin	Other (Describe)	
					Concrete Floor Only		
					Concrete Floor and Partial Concrete Walls		
5. Well is intended to supply water for: <u>Private</u>				9. FORMATIONS			
				Kind	From (ft.)	To (ft.)	
6. DRILLHOLE							
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)		
<u>10</u>	<u>0</u>	<u>8390</u>				<u>DIRT + Loose Rock</u>	<u>Surface</u> <u>24</u>
	<u>Surface</u>					<u>Soft Shale</u>	<u>24</u> <u>74</u>
<u>6</u>	<u>90</u>	<u>100</u>				<u>Shale</u>	<u>74</u> <u>80</u>
						<u>Hard Shale</u>	<u>80</u> <u>100</u>
7. CASING, LINER, CURBING AND SCREEN				10. TYPE OF DRILLING MACHINE USED			
Dia. (in.)	Mfg. & Method of Assembly	From (ft.)	To (ft.)	<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Rotary-hammer w/drilling mud & air	<input type="checkbox"/> Jetting with	
<u>6</u>	<u>New Blacksteel</u>	<u>Surface</u>	<u>8390</u>	<input type="checkbox"/> Rotary-air w/drilling mud	<input checked="" type="checkbox"/> Rotary-hammer & air	<input type="checkbox"/> Air	
	<u>Plain End</u>			<input type="checkbox"/> Rotary-w/drilling mud	<input type="checkbox"/> Reverse Rotary	<input type="checkbox"/> Water	
	<u>KSP</u>						
	<u>ASTM A-120</u>						
	<u>#18.97.280W</u>						
8. GROUT OR OTHER SEALING MATERIAL				Well construction completed on <u>4-29</u> 19 <u>86</u>			
Kind		From (ft.)	To (ft.)				
<u>Bury Tank</u>		<u>Surface</u>	<u>7</u>				
<u>Cement</u>		<u>7</u>	<u>8390</u>				
11. MISCELLANEOUS DATA				Well is terminated <u>10</u> inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below			
Yield Test: <u>2</u>	Hrs. at <u>7</u>	GPM		Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Depth from surface to normal water level <u>57</u>	Ft.			Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Depth of water level when pumping <u>69</u>	Ft.	Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No					
Water sample sent to <u>MADISON</u> laboratory on <u>5-6</u> 19 <u>86</u>							
Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.							
Signature <u>Michael D. Binbow</u> Registered Well Driller				Business Name and Complete Mailing Address <u>CORPIAN WELL DRILLING INC.</u> <u>R.R. 2 Boscobel WI.</u>			