

DEC 19 1975

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

NOTE

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE Town Village City NAME Marietta

2. LOCATION - 1/4 Section NE Section 8 Township 8N Range 5W 3. OWNER AT TIME OF DRILLING John Sime
OR - Grid or street no. Street name ADDRESS R3

AND - If available subdivision name, lot & block no. POST OFFICE Boscobel, Wis., 53805

4. Distance in feet from well to nearest: BUILDING 15' SANITARY SEWER C.I. 25' TILE FLOOR DRAIN C.I. TILE FOUNDATION DRAIN SEWER CONNECTED INDEPENDENT WASTE WATER DRAIN C.I. 25' TILE
(Record answer in appropriate block)

CLEAR WATER DRAIN C.I. TILE SEPTIC TANK PRIVY SEEPAGE PIT ABSORPTION FIELD 70' BARN SILO ABANDONED WELL SINK HOLE

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Trailer home

6. DRILLHOLE						9. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	60	6	60	160	Clay	Surface	40
						limestone	40	55
						hard shalestone	55	140
						sandstone	140	160

7. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	new black steel plain end 18.97 A-53	Surface	60
	Valley Steel		

8. GROUT OR OTHER SEALING MATERIAL Kind Cement From (ft.) Surface To (ft.) 60

10. TYPE OF DRILLING MACHINE USED
 Cable Tool Direct Rotary Reverse Rotary
 Rotary - air w/drilling mud Rotary - hammer with drilling mud & air Jetting with Air Water
 Well construction completed on 11-29-1975

11. MISCELLANEOUS DATA
 Yield test: 3 Hrs. at 8 GPM
 Well is terminated 8 inches above below final grade
 Well disinfected upon completion Yes No
 Well sealed watertight upon completion Yes No
 Depth from surface to normal water level 80 ft.
 Depth to water level when pumping 92 ft.

Water sample sent to Madison laboratory on: 12-15-1975

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Copian Registered Well Driller COMPLETE MAIL ADDRESS Boscobel, R3 Box 84 Wis., 53805

COLIFORM TEST RESULT 590 GAS - 24 HRS. GAS - 48 HRS. CONFIRMED REMARKS L
REV. 3-71