

OCT 30 1979

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Marietta

2. LOCATION 1/4 Section NW Section 9 Township 8 N Range 5 W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Kenneth Crowley
 OR - Grid or Street No. Street Name ADDRESS R 3 D 1

AND - If available subdivision name, lot & block No. POST OFFICE Steuben, Wis., 54657

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 9' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr. Sewage Sump Clearwater Sump Sewage Sump C.I. Other Clearwater Sump Clearwater Sump Holding Tank Septic Tank Sewage Absorption Unit Seepage Pit Seepage Bed Seepage Trench 80'

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Country home

9. FORMATIONS

| 6. DRILLHOLE | | | | | | Kind | From (ft.) | To (ft.) |
|--------------|----------------|-----------|------------|------------|------------|-----------------------|----------------|------------|
| Dia. (in.) | From (ft.) | To (ft.) | Dia. (in.) | From (ft.) | To (ft.) | | | |
| <u>10</u> | <u>Surface</u> | <u>20</u> | <u>6</u> | <u>20</u> | <u>100</u> | <u>Clay</u> | <u>Surface</u> | <u>20</u> |
| | | | | | | <u>loose sand</u> | <u>20</u> | <u>60</u> |
| | | | | | | <u>soft sandstone</u> | <u>60</u> | <u>70</u> |
| | | | | | | <u>hard sandstone</u> | <u>70</u> | <u>100</u> |

7. CASING, LINER, CURBING AND SCREEN
 Material, Weight, Specification & Method of Assembly
 Dia. (in.) From (ft.) To (ft.)
6 new black steel 0 90
P.E. 18.97
A - 53
Keystone Pipe
Pitless adapter

10. TYPE OF DRILLING MACHINE USED
 Cable Tool Rotary-hammer w/drilling mud & air Jetting with
 Rotary-air w/drilling mud Rotary-hammer & air Air
 Rotary-w/drilling mud Reverse Rotary Water

8. GROUT OR OTHER SEALING MATERIAL
 Kind From (ft.) To (ft.)
Clay Surface 7
Cement 7 20

Well construction completed on 10-1- 19 79

11. MISCELLANEOUS DATA
 Yield Test: 3 Hrs. at 5 GPM
 Depth from surface to normal water level 60 Ft.
 Depth of water level when pumping 72 Ft. Stabilized Yes No

Well is terminated 12 inches above below final grade
 Well disinfected upon completion Yes No
 Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 10-22- 19 79

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Crowley Registered Well Driller Complete Mail Address Boacobel, Wis., R 2 Box 4 53805