

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

JAN 30 1976

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

NOTE

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE Town Village City NAME Eastman

2. LOCATION - 1/4 Section SE Section 10 Township 8N Range 5W 3. OWNER AT TIME OF DRILLING Charles Stuckey

OR - Grid or street no. Street name ADDRESS R7D

AND - If available subdivision name, lot & block no. POST OFFICE Steubens, Wis. 54657

4. Distance in feet from well to nearest:

BUILDING	SANITARY SEWER C.I.	FLOOR DRAIN C.I.	FOUNDATION DRAIN SEWER CONNECTED	FOUNDATION DRAIN INDEPENDENT	WASTE WATER DRAIN C.I.
<u>40'</u>	<u>60'</u>				

CLEAR WATER DRAIN C.I.	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILLO	ABANDONED WELL	SINK HOLE
	<u>80'</u>			<u>90'</u>				

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Country home

6. DRILLHOLE						9. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>45</u>	<u>6</u>	<u>45</u>	<u>80</u>	<u>Clay</u>	<u>Surface</u>	<u>35</u>
						<u>hard shalestone</u>	<u>35</u>	<u>80</u>

7. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel plain end 18.97 A-53</u>	<u>Surface</u>	<u>45</u>
	<u>Valley Steel Pitless units</u>		

8. GROUT OR OTHER SEALING MATERIAL			10. TYPE OF DRILLING MACHINE USED		
Kind	From (ft.)	To (ft.)	<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Direct Rotary	<input type="checkbox"/> Reverse Rotary
<u>Puddled Clay</u>	<u>Surface</u>	<u>10</u>	<input type="checkbox"/> Rotary - air w/drilling mud	<input checked="" type="checkbox"/> Rotary - hammer with drilling mud & air	<input type="checkbox"/> Jetting with <input type="checkbox"/> Air <input type="checkbox"/> Water
<u>Cement</u>	<u>10</u>	<u>45</u>	Well construction completed on <u>1-5-1976</u>		

11. MISCELLANEOUS DATA		
Yield test:	<u>3 Hrs. at</u>	<u>5 GPM</u>
Depth from surface to normal water level	<u>40 ft.</u>	Well is terminated <u>12</u> inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade
Depth to water level when pumping	<u>46 ft.</u>	Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
		Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No

Water sample sent to Madison laboratory on: 1-26-1976

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Cyprian Registered Well Driller COMPLETE MAIL ADDRESS Boscobel, Wis. 53805
R3 Box 84

Please do not write in space below

COLIFORM TEST RESULT <u>593</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
------------------------------------	---------------	---------------	-----------	---------